

BCA Green Mark Certification Standard for Existing Buildings

GM Version 3.0



The BCA Green Mark Certification Standard for Existing Buildings (GM Version 3.0) is electronically published by the Building and Construction Authority.

© Building and Construction Authority, January 2016

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, without permission in writing from the publisher.

Addendums and Updates

Addendums and Updates	Page	DATE
GM Certification Standard Version 3.0		January 2016

BCA Green Mark
Certification Standard
For Existing Buildings

GM Version 3.0

January 2016

Contents

BCA GREEN MARK CERTIFICATION STANDARD FOR EXISTING BUILDINGS

1	Introduction	1
2	Scope	2
3	Nominative References.....	2
4	Terms and Definitions.....	2
5	Certification Process	3
6	Assessment Frameworks.....	4
7	Documentation Requirements.....	22

1 INTRODUCTION

The intent of this Certification Standard for Existing Buildings (referred to as “Standards”) is to guide owners of existing buildings to improve the minimum sustainability standards of existing buildings and establish environmentally friendly practices in the operation and retrofitting of existing buildings

This Standard sets out the requirements for assessing the environmental performance of an existing building.

This Standard is not intended to abridge safety, health, environmental or related requirements contained in other applicable laws, codes or policies administered by relevant authorities. Where there is a conflict between a requirement of this Standard and such other laws affecting the design and retrofit of the building, the laws shall take precedence.

If you need clarification on any aspect of this Standard, please contact the Building and Construction Authority, Singapore (BCA).

The contents of this Standard are protected by copyright and other forms of proprietary rights. All rights, title and interest in the contents are owned by, licensed to or controlled by BCA and shall not be reproduced, republished, uploaded, posted, transmitted or otherwise distributed in any way, without the prior written permission of BCA. Modification of any of the contents or use of the contents for any other purpose will be a violation of BCA's copyright and other intellectual property rights.

2 SCOPE

This Standard sets out the requirement for assessing the environmental performance of a building development. It provides the assessment criteria in determining the level of environmental performance of a building development

The provision of this Standard are applicable to:

- a. Existing buildings and related building systems

3 NORMATIVE REFERENCES

The following referenced codes, standards and other documents referred in this standard shall be considered part of the requirements of this Standard to the extend as prescribed.

- a. Code on Envelope Thermal Performance for Buildings
- b. CP 24:1999 - Code of Practice for Energy Efficiency Standard for Building Services and Equipment
- c. CP 13:1999 - Code of Practice for Mechanical ventilation and Air-Conditioning in Buildings
- d. CP 38:1999 - Code of Practice for Artificial Lighting in Buildings
- e. SS 531:Part 1: 2006 - Code of Practice for Lighting of Work Places, Part 1 : Indoor
- f. SS 554:2009 - Code of Practice for Indoor Air Quality for Air-conditioned Buildings
- g. NEA's Guidelines for Good Indoor Air Quality in Office Premises
- h. ASHRAE Guideline 22 – Instrumentation for Monitoring Central Chilled water Plant Efficiency by American Society of Heating, Refrigerating and Air-Conditioning Engineer (ASHRAE)
- i. AHRI Standard 550/590 – Performance Rating of Water Chilling and Heat Pump Water–Heating Packages Using the Vapour Compression Cycle by Air-Conditioning, Heating and Refrigeration Institute(AHRI)

4 TERMS AND DEFINITIONS

For the purpose of this Standard, the following definitions shall apply:

BCA	The Building and Construction Authority
Chilled Water Plant	A building's centralised air conditioning system which makes use of chilled water as the medium for removing the heat from the buildings. This includes the chillers and its ancillary equipment, including pumps and cooling towers where applicable.
Gross Floor Area (GFA)	The "gross floor area" has the same meaning as "floor area" in the Planning (Development Charges) Rules (Cap.232, R 5)
Minimum Green Mark Score	The lowest Green Mark score that would meet the minimum environmental performance required for existing buildings.

Operational System Efficiency (OSE)

The measured system efficiency of the building’s chilled water plant during its normal operating hours.


Unitary Air Conditioning System

One or more factory-made assemblies that normally include an evaporator or cooling coil and a compressor combination. Units that perform a heating function area are also included.

In instances where terms are not expressly stated in this Code and are defined in other referenced documents, such terms shall have the meanings as determined in those documents.

5 CERTIFICATION PROCESS

The BCA Green Mark Certification Process is as follows:



6 ASSESSMENT FRAMEWORK

6.1 General

The environmental performance of an existing building shall be determined by the level of environmental performance and the numerical scores (i.e. Green Mark points) achieved in accordance with the degree of compliance with the applicable criteria using the scoring methodology as specified in this Standard. Under this assessment framework, points are awarded for incorporating sustainable green features and practices, which would add up to a final Green Mark Score. Depending on the level of building's performance and Green Mark Score, the existing building will be eligible for certification under one of the four ratings namely BCA Green Mark Certified, Gold, Gold^{Plus}, or Platinum (see table 6.1). The framework and point allocations for the assessment criteria are as illustrated in Table 6.2 and 6.3.

6.2 Environmental Performance of Buildings for Certification

The Green Mark Score of an existing building is the total of all the numerical scores (i.e. Green Mark points) assigned based on the degree of compliance with the applicable criteria. The following table 6.1 states the corresponding Green Mark Score and prerequisite requirements to attain the respective Green Mark rating namely the BCA Green Mark Certified, Gold, Gold^{Plus}, or Platinum.

Table 6.1. BCA Green Mark Award Rating and Prerequisite Requirements

Green Mark Score	Green Mark Rating
90 and above	Green Mark Platinum
85 to <90	Green Mark Gold ^{Plus}
75 to <85	Green Mark Gold
50 to <75	Green Mark Certified

Pre-requisite Requirements for Existing Non-residential Building Criteria		
<u>PART 1 - ENERGY EFFICIENCY</u>		
1. ENERGY EFFICIENCY		
Green Mark Rating	Minimum points achievement from Part 1 – Energy Efficiency	
Green Mark Certified	30 points	
Green Mark Gold	35 points	
Green mark Gold ^{Plus}	40 points	
Green Mark Platinum	45 points	
2. MINIMUM SYSTEMS' EFFICIENCY		
Minimum Design System Efficiency/Operating System Efficiency (DSE/OSE)		
(i) For buildings using Water-Cooled Chilled-Water Plant		
Green Mark Rating	Building Cooling Load (RT)	
	< 500	≥ 500
	Efficiency (kW/RT)	
Certified	0.85	0.75
Gold	0.80	0.70
Gold ^{Plus}	0.75	0.68
Platinum	0.70	0.65

(ii) For Buildings using Air Cooled Chilled-water Plant or Unitary Air-Conditioner

Green Mark Rating	Building Cooling Load (RT)	
	< 500	≥ 500
	Efficiency (kW/RT)	
Certified	1.1	1.0
Gold	1.0	Not applicable
Gold ^{Plus}	0.85	
Platinum	0.78	

For building with building cooling load of more than 500 RT, the use of air cooled central chilled-water plant or other unitary air-conditioners are not applicable for Gold and higher ratings.

Note: The performance of the overall air-conditioning system for the building is based on the Operating System Efficiency (OSE) of the system during the normal building operating hours as defined below:

<u>Office Building:</u> Monday to Friday: 9am to 6pm	<u>Hotel and Hospital:</u> 24-hour
<u>Retail Mall:</u> Monday to Sunday: 10am to 9pm	<u>Industrial and Other Building Types:</u> To be determined based on the operating hours
<u>Institutional:</u> Monday to Friday: 9am to 5pm	

3. CHILLER PLANT M&V INSTRUMENTATION

- (i) Provision of permanent measuring instruments for monitoring of water-cooled chilled-water system and air-cooled chilled water system operating system efficiency. The installed instrumentation shall have the capability to calculate resultant plant operating system efficiency (i.e. kW/RT) within 5% of its true value and in accordance with ASHRAE Guide 22 and AHRI 550/590. Heat balance test for water-cooled chilled-water system is required for verification of the accuracy of the M&V instrumentation.

4. NATURAL VENTILATION AREA (only applicable to occupied areas, excluding circulation, plant rooms and transit areas):

Pre requisite requirement for Platinum - At least 75% of natural ventilated areas with effective cross ventilation with North and South facing window opening

PART 4 - INDOOR ENVIRONMENTAL QUALITY

1. IAQ Audit - to conduct an full IAQ audit three yearly that complies with NEA's Guidelines for Good Indoor Air Quality in Office Premises or SS554:2009 Code of Practice for 'Indoor air quality for air-conditioned buildings' [4 points] [ENRB 4-1(a)]

6.3 Assessment Criteria

The environmental impact categories are broadly classified under two main groupings:

- (i) Energy Efficiency consists of Part 1- Energy Efficiency where points are allocated for the various energy efficient systems, practices and features used. A minimum of 30 points must be obtained from this group to meet the minimum environmental sustainability standard.
- (ii) Other Green Requirements consist of Part 2 – Water Efficiency; Part 3 – Sustainable Operation & Management; Part 4 – Indoor Environmental Quality; and, Part 5 – Other Green Features. Points are allocated for the water efficient features, use of environmental friendly practices, waste management and innovative green features used. A minimum of 20 points must be obtained from this group to comply with the minimum environmental sustainability standard.

The intent of each category is summaries as below:

- (a) Part 1 – Energy Efficiency: This category focuses on greater use of energy efficient building system including air-conditioning, ventilation, lightings, lifts and escalators; and also monitoring of these systems. It also looks at applications of renewable energy and energy efficient features.

Important Note:

Part 1 – Energy Efficiency applies to both air-conditioned and non air-conditioned spaces. Where there is a combination of air-conditioned and non air-conditioned spaces, the points allocated are to be pro-rated in accordance with the respective floor areas. For simplicity, points applicable to air-conditioned areas are accounted only if the aggregate air-conditioned areas exceed 500 m². Similarly, points applicable to non air-conditioned areas are accounted only if the aggregate non air-conditioned areas are more than 10% of the total floor areas excluding carpark and common areas.

- (b) Part 2 – Water Efficiency: This category focuses on the use of water efficient fittings and adoption of water efficient features, which can help to reduce the use of water for building operations.
- (c) Part 3 – Sustainable Operation & Management: This category focuses on the building management operation and maintenance, the use of sustainable and environmental-friendly products, provision of waste management and greater use of greenery.
- (d) Part 4 – Indoor Environmental Quality: This category focuses on promoting a healthy indoor environment which includes air quality, thermal comfort, minimizing indoor air pollutants, acceptable internal noise level and encourage good lighting quality.
- (e) Part 5 – Other Green Features: This category focuses on the adoption of green practices and new technologies that are innovative and have potential environmental benefits.

Table 6.2: Framework and Point Allocation for BCA Green Mark for Existing Non-Residential Buildings Criteria (Version 3.0)

CATEGORY		POINT ALLOCATION	
(I) ENERGY EFFICIENCY			
Minimum 30 points to be scored	Part 1 – Energy Efficiency		
	ENRB 1-1 Thermal Performance of Building Envelope	5	
	ENRB 1-2 Air Conditioning System	} 32	
	ENRB 1-3 Natural Ventilation / Mechanical Ventilation		
	ENRB 1-4 Artificial Lighting	13	
	ENRB 1-5 Ventilation in Carparks	4	
	ENRB 1-6 Ventilation in Common Areas	5	
	ENRB 1-7 Lifts and Escalators	2	
	ENRB 1-8 Energy Efficient Practices & Features	12	
	ENRB 1-9 Energy Policy & Management	1	
	ENRB 1-10 Renewable Energy	15	
Category Score for Part 1 – Energy Efficiency		89	
(II) OTHER GREEN REQUIREMENTS			
Minimum 20 points to be scored	Part 2 - Water Efficiency		
	ENRB 2-1 Water Monitoring	4	
	ENRB 2-2 Water Efficient Fittings	12	
	ENRB 2-3 Alternative Water Sources	3	
	ENRB 2-4 Water Efficiency Improvement Plans	1	
	ENRB 2-5 Irrigation System and Landscaping	2	
	ENRB 2-6 Cooling Towers	2	
	Category Score for Part 2 – Water Efficiency		24
	Part 3 - Sustainable Operation & Management		
	ENRB 3-1 Building Operation & Maintenance	4	
	ENRB 3-2 Post Occupancy Evaluation	3	
	ENRB 3-3 Waste Management	7	
	ENRB 3-4 Sustainable Products	8	
	ENRB 3-5 Greenery	10	
	ENRB 3-6 Environmental Protection	3	
	ENRB 3-7 Green Transport	4	
	Category Score for Part 3 – Sustainable Operation and Management		39
	Part 4 - Indoor Environmental Quality		
	ENRB 4-1 Indoor Air Quality Performance	8	
	ENRB 4-2 Indoor Air Pollutants	2	
	ENRB 4-3 Lighting Quality	5	
	ENRB 4-4 Thermal Comfort	2	
	ENRB 4-5 Internal Noise Level	1	
Category Score for Part 4 – Indoor environment Quality		18	
Part 5 – Other Green Features			
ENRB 5-1 Green Features & Innovations	10		
Category Score for Part 5 – Other Green Features		10	
Category Score for Other Green Requirements		91	
Total Green Mark Score		180	

Table 6.3 : Existing Non-Residential Building Criteria (energy related requirements)

Part 1 - Energy Efficiency	Green Mark Points								
<p>ENRB 1-1 Thermal Performance of Building Envelope</p> <p>Enhance the overall thermal performance of building envelope to minimize heat gain thus reducing the overall cooling load requirement.</p>	<p>0.5 points for every reduction of 1 W/m² in ETTV from the baseline of 50 W/m²</p> <p>Point scored = 0.5 x (50 – ETTV)</p> <p>(Up to 5 points)</p>								
<p>ENRB 1-2 Air-Conditioning System Applicable to Air-conditioned Building Areas (with an aggregate air-conditioned areas > 500m²)</p> <p>Encourage the use of better efficiency air-conditioned equipment to minimize the energy consumption. (System efficiency in kW/ton)</p> <p>(a) Water-Cooled Chilled-Water Plant:</p> <ul style="list-style-type: none"> a) Water-Cooled Chiller b) Chilled water pump c) Condenser water pump d) Cooling tower <table border="1" data-bbox="150 965 794 1149"> <thead> <tr> <th rowspan="2">Baseline</th> <th colspan="2">Building Cooling Load</th> </tr> <tr> <th>< 500 RT</th> <th>≥500 RT</th> </tr> </thead> <tbody> <tr> <td><i>Pre-requisite Requirements</i> Minimum system efficiency of central chilled-water plant</td> <td>0.85 kW/RT</td> <td>0.75 kW/RT</td> </tr> </tbody> </table> <p style="text-align: center;">OR</p> <p>(b) Air Cooled Chilled-Water Plant / Unitary Air-Conditioners:</p> <p>Air cooled Chilled-Water Plant:</p> <ul style="list-style-type: none"> ▪ Air-Cooled Chiller ▪ Chilled Water Pump <p>Unitary Air-Conditioners:</p> <ul style="list-style-type: none"> ▪ Variable Refrigerant Flow (VRF) System ▪ Water-Cooled Package Unit ▪ Single-Split Unit ▪ Multi-Split Unit 	Baseline	Building Cooling Load		< 500 RT	≥500 RT	<i>Pre-requisite Requirements</i> Minimum system efficiency of central chilled-water plant	0.85 kW/RT	0.75 kW/RT	<p>(a) Water-Cooled Chilled-Water Plant</p> <div style="border: 1px solid black; padding: 5px; text-align: center;">Building cooling load ≥ 500RT</div> <p>14 points for achieving plant efficiency of 0.75 kW/ton</p> <p>0.35 point for every percentage improvement in the chiller plant efficiency better than 0.75 kW/ton</p> <p>Point scored = 0.35 x (% improvement)</p> <div style="border: 1px solid black; padding: 5px; text-align: center;">Building cooling load < 500RT</div> <p>14 points for achieving plant efficiency of 0.85 kW/ton</p> <p>0.3 point for every percentage improvement in the chiller plant efficiency better than 0.85 kW/ton</p> <p>Point scored = 0.3 x (% improvement)</p> <p style="text-align: center;">(Up to 20 points)</p> <p style="text-align: center;">OR</p> <p>(b) Air-Cooled Chilled-Water Plant/Unitary Air Conditioners</p> <div style="border: 1px solid black; padding: 5px; text-align: center;">Building cooling load ≥ 500RT</div> <p>14 points for achieving plant efficiency of 1.0 kW/ton</p> <p>0.25 point for every percentage improvement in the chiller plant efficiency better than 1.0 kW/ton</p> <p>Point scored = 0.25 x (% improvement)</p>
Baseline		Building Cooling Load							
	< 500 RT	≥500 RT							
<i>Pre-requisite Requirements</i> Minimum system efficiency of central chilled-water plant	0.85 kW/RT	0.75 kW/RT							

Part 1 - Energy Efficiency		Green Mark Points														
<table border="1"> <thead> <tr> <th rowspan="2">Baseline</th> <th colspan="2">Building Cooling Load</th> </tr> <tr> <th>< 500 RT</th> <th>≥500 RT</th> </tr> </thead> <tbody> <tr> <td><i>Pre-requisite Requirements</i> Minimum system efficiency of air cooled chilled water plant or unitary conditioners</td> <td>1.1 kW/RT</td> <td>1.0 kW/RT</td> </tr> </tbody> </table> <p>Note: Where there is a combination of centralised air-con system with unitary air-conditioned system, the computation for the points scored will only be based on the air-conditioning system with a larger aggregate capacity.</p> <p>(c) Air Distribution system:</p> <ul style="list-style-type: none"> • Air Handling Units (AHUs) • Fan Coil Units (FCUs) <p>Baseline – Fan power limitation in air conditioning system</p> <table border="1"> <thead> <tr> <th colspan="2">Allowable nameplate motor power</th> </tr> <tr> <th>Constant volume</th> <th>Variable volume</th> </tr> </thead> <tbody> <tr> <td>0.47 W/CMH</td> <td>0.74 W/CMH</td> </tr> </tbody> </table> <p>Note: For buildings using district cooling system, there is no need to compute the plant efficiency under Part 1-2 (a) and (b). The points obtained will be pro-rated based on the air distribution system efficiency under Part 1-2(c)</p> <p>(d) <i>Prerequisite requirements</i>: Provision of permanent measuring instruments for monitoring of water-cooled chilled-water plant and air-cooled chilled-water plant efficiency. The installed instrumentation shall have the capability to calculate a resultant plant efficiency (i.e. kW/RT) within 5% of its true value and in accordance with ASHRAE Guide 22 and AHRI 550/590. The following instrumentation and installation are also required to be complied with:</p> <ul style="list-style-type: none"> • Location and installation of the measuring devices to meet the manufacturer’s recommendation. • Data acquisition system to have a minimum resolution of 16 bit. • All data logging with capability to trend at 1 minute sampling time interval. • Dedicated digital power meters shall be provided for the following groups of equipments: chiller(s), chilled water pump(s), condenser water pump(s) and cooling tower(s). • Flow meters to be provided for chilled-water and condenser water loop and shall be of ultrasonic / full bore magnetic type or equivalent. • Temperature sensors are to be provided for chilled water and condenser water loop and shall have an end-to-end measurement uncertainty not exceeding ± 0.05 °C over entire measurement or calibration range. All thermo-wells shall be installed in a manner that ensures that the sensors can be in direct contact with fluid flow. Provisions shall be made for each temperature measurement location to have two spare thermo-wells located at both side of the temperature sensor for verification of measurement accuracy. 		Baseline	Building Cooling Load		< 500 RT	≥500 RT	<i>Pre-requisite Requirements</i> Minimum system efficiency of air cooled chilled water plant or unitary conditioners	1.1 kW/RT	1.0 kW/RT	Allowable nameplate motor power		Constant volume	Variable volume	0.47 W/CMH	0.74 W/CMH	<div style="border: 1px solid black; padding: 5px; text-align: center; margin-bottom: 10px;"> Building cooling load < 500RT </div> <p>14 points for achieving plant efficiency of 1.1 kW/ton</p> <p>0.2 point for every percentage improvement in the chiller plant efficiency better than 1.1 kW/ton</p> <p>Point scored = 0.2 x (% improvement) (Up to 20 points)</p> <p>(c) Air Distribution System 0.15 point for every percentage improvement in the air distribution system efficiency over the baseline</p> <p>Point scored = 0.15 x (% improvement) (Up to 8 points)</p> <p style="text-align: center;">1 point</p>
Baseline	Building Cooling Load															
	< 500 RT	≥500 RT														
<i>Pre-requisite Requirements</i> Minimum system efficiency of air cooled chilled water plant or unitary conditioners	1.1 kW/RT	1.0 kW/RT														
Allowable nameplate motor power																
Constant volume	Variable volume															
0.47 W/CMH	0.74 W/CMH															

Part 1 - Energy Efficiency	Green Mark Points						
<p>(e) <i>Prerequisite requirements:</i> Verification of central water cooled chilled-water plant instrumentation: Heat Balance – substantiating test for water cooled chilled-water plant to be computed in accordance with AHRI 550/590. The operating system efficiency and heat balance to be submitted to BCA upon commissioning.</p> <p>(f) Provision of variable speed controls for chiller plant equipment such as chilled-water pumps and cooling tower fans to ensure better part-load plant efficiency.</p> <p>(g) Sensors or similar automatic control devices are used to regulate outdoor air flow rate to maintain the concentration of carbon dioxide.</p> <p>Carbon dioxide acceptable range ≤ 700 ppm above outdoor</p>	<p>1 point</p> <p>1 point</p> <p>1 point</p>						
<p>ENRB 1-3 Natural Ventilation / Mechanical Ventilation</p> <p>Applicable to Non Air-Conditioned Building Areas (with an aggregate non air-conditioned areas > 10% of total floor area excluding carpark and common areas)</p> <p>(a) <u>Natural Ventilation</u> (only applicable to occupied areas, excluding circulation, plant rooms and transit areas) Encourage building that facilitates good natural ventilation. Proper design of building layout that utilises prevailing wind conditions to achieve adequate cross ventilation.</p> <p>(b) <u>Mechanical Ventilation</u> Encourage energy efficient mechanical ventilation system as the preferred ventilation mode to air-conditioning in buildings.</p> <p>Baseline: Fan power limitation I mechanical ventilation systems:</p> <table border="1" data-bbox="204 1473 738 1570"> <thead> <tr> <th colspan="2">Allowable nameplate motor power</th> </tr> <tr> <th>Constant volume</th> <th>Variable volume</th> </tr> </thead> <tbody> <tr> <td>0.47 W/CMH</td> <td>0.74 W/CMH</td> </tr> </tbody> </table> <p>Note : Where there is a combination of naturally ventilated and mechanical ventilated spaces, the points scored will only be based on the predominant ventilation modes of normally occupied spaces.</p>	Allowable nameplate motor power		Constant volume	Variable volume	0.47 W/CMH	0.74 W/CMH	<p>20 based points will be awarded for use of natural ventilation</p> <p>1.6 points for every 10% of NV areas with window openings facing north and south directions and cross ventilation (Up to 32 points)</p> <p>0.6 point for every subsequent 1% improvement from the baseline (Up to 32 points)</p>
Allowable nameplate motor power							
Constant volume	Variable volume						
0.47 W/CMH	0.74 W/CMH						
<p>ENRB 1-4 Artificial Lighting</p> <p>Encourage the use of energy efficient lighting to minimize energy consumption from lighting usage while maintaining proper lighting level.</p> <p>Please refer to the Annex 1 for the baselines of lighting power budget</p>	<p>0.3 point for every percentage improvement in lighting power budget</p> <p>Point scored = $0.3 \times (\% \text{ improvement})$</p> <p>(Up to 13 points)</p> <p>Excluding tenant lighting provision – Up to 5 points)</p>						

Part 1 - Energy Efficiency	Green Mark Points
<p>ENRB 1-5 Ventilation in Carparks</p> <p>Encourage the use of energy efficient design and control of ventilation systems in carparks.</p> <ul style="list-style-type: none"> (a) Carparks designed with natural ventilation. (b) CO sensors are used to regulate the demand for mechanical ventilation (MV) <p>Note: Where there is a combination of different ventilation mode adopted for carpark design, the points obtained will be prorated accordingly.</p>	<p>Naturally ventilated carparks – 4 points</p> <p>Points scored based on the mode of mechanical ventilation provided</p> <p>Fume extract – 2.5 points MV with or without supply – 2 points</p> <p>(Up to 4 points)</p>
<p>ENRB 1-6 Ventilation in Common Areas</p> <p>Encourage the use of energy efficient of ventilation systems in the following common areas:</p> <ul style="list-style-type: none"> (a) Toilets (b) Staircases (c) Corridors (d) Lift lobbies (e) Atrium 	<p>Extent of Coverage: At least 90% of each applicable area</p> <p>Point scored based on the mode of ventilation provided in the applicable areas</p> <p>Natural ventilation – 1.5 points for each area Mechanical ventilation – 0.5 point for each area</p> <p>(Up to 5 points)</p>
<p>ENRB 1-7 Lifts and Escalators</p> <p>Encourage the use of energy efficient lifts and escalators.</p> <p>Lifts and/or escalators with AC variable voltage and variable frequency (VVVF) motor drive and sleep mode features.</p>	<p>Extent of Coverage: All lifts and escalators</p> <p>Lifts – 1 point Escalators- 1 point</p>
<p>ENRB 1-8 Energy Efficient Practices & Features</p> <p>Encourage the use of energy efficient practices and features which are innovative and/or have positive environmental impact.</p> <ul style="list-style-type: none"> (a) Computation of the energy consumption in the form of energy efficiency index (EEI) (b) Use of energy efficient products that are certified by approved local certification body (c) Use of energy efficient features Example: <ul style="list-style-type: none"> • Re-generative lift • Heat recovery system • Motion sensors • Sun pipes • Light shelves • Photocell sensors to maximize the use of daylight • Heat pumps, etc. 	<p>1 point</p> <p>0.5 point for each equipment type (Up to 2 points)</p> <p>2 points for every 1% energy saving over the total building energy consumption (Up to 9 points)</p>

Part 1 - Energy Efficiency	Green Mark Points											
<p>ENRB 1-9 Energy Policy and Management</p> <p>(a) Energy policy, energy targets and regular review with top management's commitment as part of an environmental strategy</p> <p>(b) To show intent, measures and implementation strategies of energy efficiency improvement plans to achieve energy target set over the next three years. Committed energy savings accrued from proposed measures should be quantified.</p>	<p>0.5 point</p> <p>0.5 point</p>											
<p>ENRB 1-10 Renewable Energy</p> <p>Encourage the application of renewable energy sources in buildings.</p>	<p>Point scored based on the expected energy efficiency index (EEI) and % replacement of electricity by renewable energy source</p> <table border="1" data-bbox="833 779 1394 1043"> <thead> <tr> <th rowspan="2">Energy Efficiency Index (EEI)</th> <th colspan="2">Every 1% replacement of electricity (based on total electricity consumption) by renewable energy source</th> </tr> <tr> <th>Include tenant's usage</th> <th>Exclude tenant's usage</th> </tr> </thead> <tbody> <tr> <td>≥ 50 kWh/m²/yr</td> <td>5 points</td> <td>3 points</td> </tr> <tr> <td>< 50 kWh/m²/yr</td> <td>3 points</td> <td>1.5 points</td> </tr> </tbody> </table> <p>(Up to 15 points)</p>	Energy Efficiency Index (EEI)	Every 1% replacement of electricity (based on total electricity consumption) by renewable energy source		Include tenant's usage	Exclude tenant's usage	≥ 50 kWh/m ² /yr	5 points	3 points	< 50 kWh/m ² /yr	3 points	1.5 points
Energy Efficiency Index (EEI)	Every 1% replacement of electricity (based on total electricity consumption) by renewable energy source											
	Include tenant's usage	Exclude tenant's usage										
≥ 50 kWh/m ² /yr	5 points	3 points										
< 50 kWh/m ² /yr	3 points	1.5 points										
<p>PART 1 – ENERGY EFFICIENCY CATEGORY SCORE:</p>	$\frac{(\text{Part 1-2}) \times \text{Air-conditioned Building Floor Area}}{\text{Total Floor Area}} + \frac{(\text{Part 1-3}) \times \text{Non Air-Conditioned Building Floor Area}}{\text{Total Floor Area}} + (\text{Part 1-1, Part 1-4 to Part 1-10})$ <p>Where Part 1-2 = Total Green Mark Points obtained under Part 1-2</p> <p>Part 1-3 = Total Green Mark Points obtained under Part 1-3</p> <p>Part 1-1, Part 1-4 to Part 1-10 = Total Green Mark Points obtained under Part 1-1, Part 1-4 to Part 1-10</p>											

Part 2 - Water Efficiency	Green Mark Points										
<p>ENRB 2-1 Water Monitoring</p> <p>Provide private-metering and leak detection system for better control and monitoring.</p> <p>(a) To monitor the water consumption on monthly basis</p> <p>(b) Provision of private-meters for major water uses (e.g. cooling tower, water features, irrigation, swimming pools, tenants' usage)</p> <p>(c) Provision of automated / smart metering for monitoring and leak detection.</p>		<p>1 point</p> <p>1 point</p> <p>2 point</p>									
<p>ENRB 2-2 Water Efficient Fittings</p> <p>Encourage the use of water efficient fittings under Water Efficiency Labelling Scheme (WELS) or adopt equivalent water efficient flow-rate/flush volumes for water fittings:-</p> <ul style="list-style-type: none"> ▪ Basin taps and mixers ▪ Showers ▪ Sink/Bib taps and mixers ▪ Urinals and Urinal Flush Valves ▪ Dual-Flush Low Capacity Flushing Cisterns <p style="text-align: center;">Or</p> <p>To have PUB Water-Efficient Building Certificate.</p>	<table border="1" style="width: 100%; text-align: center;"> <tr> <td colspan="2">Rating based on Water Efficiency Labeling Scheme (WELS)</td> <td rowspan="4">Points scored based on the number and water efficiency rating of the fitting type used (up to 12 points)</td> </tr> <tr> <td>Very Good</td> <td>Excellent</td> </tr> <tr> <td colspan="2">Weightage</td> </tr> <tr> <td>9</td> <td>12</td> </tr> </table>	Rating based on Water Efficiency Labeling Scheme (WELS)		Points scored based on the number and water efficiency rating of the fitting type used (up to 12 points)	Very Good	Excellent	Weightage		9	12	<p>9 points</p>
Rating based on Water Efficiency Labeling Scheme (WELS)		Points scored based on the number and water efficiency rating of the fitting type used (up to 12 points)									
Very Good	Excellent										
Weightage											
9	12										
<p>ENRB 2-3 Alternative Water Sources</p> <p>Use of suitable systems that utilize alternative water sources for non-potable uses: irrigation, washing, water features, toilet flushing, etc (excluding cooling tower make up water) to reduce use of potable water. Alternative sources can include rainwater, greywater (for toilet flushing only), NEWater, AHU condensate and recycled water from approved sources.</p>	<p>Points awarded based on % reduction in total potable water usage of the applicable uses</p> <p>> 50 % - 3 points</p> <p>≥ 10 % to 50 % - 2 points</p> <p>< 10 % - 1 point</p> <p>(Up to 3 points)</p>										
<p>ENRB 2-4 Water Efficiency Improvement Plans</p> <p>Targets to improve building water performance against own building water performance baseline should be set. To show intent, measures and implementation strategies of water efficiency improvement plans over the next three years. Committed water savings accrued from proposed measures should be quantified. (PUB water efficiency management plan is acceptable as evidence)</p>		<p>1 point</p>									

Part 2 - Water Efficiency	Green Mark Points
<p>ENRB 2-5 Irrigation System and Landscaping</p> <p>(a) Use of automatic water efficient irrigation system with rain sensor, soil moisture sensor or equivalent control system.</p> <p>(b) Use of drought tolerant plants that require minimal irrigation.</p>	<p>Extent of Coverage: At least 50% of the landscape areas are served by the system 1 point</p> <p>Extent of Coverage: At least 50% of the landscape areas 1 point</p>
<p>ENRB 2-6 Cooling Towers</p> <p>Reduce potable water use for cooling purpose.</p> <p>(a) Use of cooling tower water treatment system which can achieve 7 or better cycles of concentration at acceptable water quality.</p> <p>(b) Use of NEWater or on-site recycled water from approved sources.</p>	<p>1 point</p> <p>1 point</p>
<p>PART 2 – WATER EFFICIENCY CATEGORY SCORE :</p>	<p>Sum of Green Mark Points obtained from ENRB 2-1 to 2-6</p>

Part 3 - Sustainable Operation & Management	Green Mark Points
<p>ENRB 3-1 Building Operation & Maintenance</p> <p>(a) The environmental policy that reflects the sustainability goals set.</p> <p>(b) A green guide for the occupants or visitors should be disseminated through various channels. Best practices to reduce energy use, water use and maintain a good indoor environment should be documented in this green guide. To demonstrate evidences of occupant involvement in environmental sustainability.</p> <p>(c) In-house building management team comprises one Certified Green Mark Facilities Manager (GMFM), Singapore Certified Energy Manager (SCEM) / Green Mark Professional (GMP).</p> <p>(d) The environmental management system of the building is ISO14000 or ISO 50001 certified.</p>	<p>1 point</p> <p>1 point</p> <p>0.5 point for certified GMFM 1 point for certified SCEM / GMP (Up to 1 point)</p> <p>1 point</p>
<p>ENRB 3-2 Post Occupancy Evaluation</p> <p>(a) Conduct post occupancy survey for occupant's satisfaction on energy and environmental performance.</p> <p>Required number of people surveyed shall be:</p> <ul style="list-style-type: none"> - 10% of total occupancy and up to 100 maximum. - minimum 5 people shall be surveyed if total occupancy is less than 50. <p>(b) List of corrective actions taken following the post occupancy evaluation, if any.</p>	<p>2 points</p> <p>1 point</p>
<p>ENRB 3-3 Waste Management</p> <p>a) Provision of facilities or recycling bins for collection and storage of different recyclable waste such as paper, glass, plastic, food waste, etc.</p> <p>b) Promote and encourage waste minimization and recycling among occupants, tenants and visitors through various avenues.</p> <p>c) Provide the proper storage area for the recyclable waste.</p> <p>d) To quantify and monitor the recycling programme for continuous improvement.</p>	<p>2 points</p> <p>2 points</p> <p>1 point</p> <p>2 points</p>

Part 3 - Sustainable Operation & Management	Green Mark Points			
<p>ENRB 3-4 Sustainable Products</p> <p>Promote use of environmentally friendly products that are certified by approved local certification body.</p>	Weightage based on the extent of environmental friendliness of products			<p>Points scored based on the weightage and the extent of coverage & impact</p> <p>1 point for high impact item</p> <p>0.5 point for low impact item</p> <p>(Up to 8 points)</p>
<p>ENRB 3-5 Greenery</p> <p>Encourage greater use of greenery to reduce heat island effect.</p> <p>(a) Greenery Provision (GnP) is calculated by considering the 3D volume covered by plants using the following Green Area Index (GAI) :</p> <p>Grass GAI = 1 ; Shrubs GAI = 3; Palms Trees GAI = 4; Trees GAI = 6</p> <p>(b) Use of compost recycled from horticulture waste.</p> <p>(c) Provision of roof top greenery</p> <p>(d) Provision of Vertical Greenery</p>	Good	Very Good	Excellent	<p>GnP = 0.5 to < 1.0 - 1 point</p> <p>GnP = 1.0 to < 2.0 - 2 points</p> <p>GnP = 2.0 to < 3.0 - 3.5 points</p> <p>GnP ≥ 3.0 - 5 points</p> <p>(Up to 5 points)</p> <p>1 point</p> <p><u>For roof top greenery areas</u></p> <p>≥ 20% & 50% of useable roof areas - 1 point</p> <p>≥ 50% of useable roof areas - 2 points</p> <p><u>For Vertical greenery areas</u></p> <p>≥10m² and <50m² - 1 point</p> <p>≥ 50m² - 2 points</p>
<p>ENRB 3-6 Environmental Protection</p> <p>(a) Green procurement policy – Adoption of sustainable and environmental-friendly procurement and purchasing policy in the operation and maintenance of the building.</p> <p>(b) Reduce the potential damage to the ozone layer and the increase in global warming through the release of ozone depleting substances and greenhouse gases.</p> <ul style="list-style-type: none"> • Refrigerants with ozone depletion potential (ODP) of zero or with global warming potential (GWP) of less than 100. ▪ Use of refrigerant leak detection system at critical areas of plant rooms containing chillers and other equipments with refrigerants. 			1 point	<p>1 point</p> <p>1 point</p> <p>1 point</p>

Part 3 - Sustainable Operation & Management	Green Mark Points
<p>ENRB 3-7 Green Transport</p> <p>Promote the use of public transport or bicycles to reduce pollution from individual car use with the following provision:</p> <p>(a) Good access to nearest MRT/LRT or bus stops.</p> <p>(b) Provision of covered walkway to facilitate connectivity and the use of public transport</p> <p>(c) Provision of priority parking lots for hybrid/electric vehicle within the development</p> <p>(d) Provision of sheltered bicycle parking lots with adequate shower and changing facilities.</p>	<p>1 point</p> <p>1 point</p> <p>1 point</p> <p>Extent of Coverage : Minimum 10 number of bicycle parking lots, cap at 30 where applicable</p> <p>Points scored based on the number of bicycle parking lots provided (with adequate shower and changing facilities)</p> <p>1 point if the number provided $\geq 1\% \times \text{GFA}/10$</p> <p>0.5 point if the number provided $\geq 0.5\% \times \text{GFA}/10$</p>
<p>PART 3 – SUSTAINABLE OPERATION AND MANAGEMENT</p> <p>CATEGORY SCORE :</p>	<p>Sum of Green Mark Points obtained from ENRB 3-1 to 3-7</p>

Part 4 – Indoor Environmental Quality	Green Mark Points
<p>ENRB 4-1 Indoor Air Quality Performance</p> <p>To promote a healthy indoor environment.</p> <p>(a) <i>Prerequisite Requirements:</i> To conduct full IAQ audit once in three years that complies with NEA’s Guidelines for Good Indoor Air Quality in Office Premises or SS554:2009 Code of Practice for ‘Indoor air quality for air-conditioned buildings’ by an accredited laboratory under the Singapore Accreditation Council.</p> <p>(b) Implement effective IAQ management plan to ensure building ventilation systems are frequently maintained to ensure or clean delivery of air.</p> <p>(c) Use of high efficiency air filter (at least MERV 13) in AHU to reduce indoor contaminants and provide good protection for cooling coil and reducing frequency or eliminating duct cleaning</p> <p>(d) Room temperature display (at least 1 unit per floor)</p> <p>(e) Additional carbon dioxide sensor display (at least 1 unit per floor)</p>	<p>4 points</p> <p>1 point</p> <p>1 point</p> <p>1 point</p> <p>1 point</p>
<p>ENRB 4-2 Indoor Air Pollutants</p> <p>Minimise airborne contaminants, mainly from inside sources to promote a healthy indoor environment.</p> <p>(a) Use of low volatile organic compounds (VOC) paints certified by an approved local certification body.</p> <p>(b) Use of environmental friendly adhesives certified by an approved local certification body.</p>	<p>1 point</p> <p>1 point</p>
<p>ENRB 4-3 Lighting Quality</p> <p>To encourage good workplace lighting quality to promote productivity and occupant comfort</p> <p>(a) Lighting level to comply with SS531:Part 1:2006 or CP38:1999 for various uses.</p> <p>(b) Controllability of lighting system</p>	<p>1 point</p> <p>At least 90% of occupants are able to adjust lighting to suit their task needs and preference</p> <p>Controlled by light switches - 1 point Controlled by task lights - 2 points</p> <p>(Up to 2 points)</p>

Part 4 – Indoor Environmental Quality	Green Mark Points
(c) High frequency ballast	<p>All applicable areas in the entire building that are served by fluorescent lightings</p> <p>20% to < 40% - 0.5 point 40% to < 60% - 1 point 60% to < 80% - 1.5 points 80% and above - 2 points</p> <p>(Up to 2 points)</p>
<p>ENRB 4-4 Thermal Comfort</p> <p>(a) Ensure the consistent indoor conditions for thermal comfort: Indoor dry-bulb temperature within 22.5 °C to 25.5 °C and relative humidity <70%</p> <p>(b) Controllability of temperature</p>	<p>1 point</p> <p>1 point</p>
<p>ENRB 4-5 Internal Noise Level</p> <p>Ensure internal noise level are maintained at an appropriate levels and to comply with CP13:1999 or SS553:2009</p>	<p>1 point</p>
<p>PART 4 – INDOOR ENVIRONMENTAL QUALITY CATEGORY SCORE :</p>	<p>Sum of Green Mark Points obtained from ENRB 4-1 to 4-5</p>

Part 5 – Other Green Features	Green Mark Points
<p>ENRB 5-1 Green Features and Innovations</p> <p>To encourage the use of other green features which are innovative and/or have positive environmental impact.</p> <p>Examples :</p> <ul style="list-style-type: none"> • Tenants with Green Mark for Office Interior or Restaurant • Green Lease • Ultraviolet light-C band (UV) emitters in air handling units (AHUs) to improve indoor air quality • Provision of carpark guidance system • Use of self cleaning façade system • Use of grey water recycling system • Titanium Dioxide coating to remove odour in toilets • Use of pneumatic waste collection system • Use of double refuse chutes for separating recyclable from non-recyclable wastes • Stormwater management • Power meter to monitor air side systems • Green Mark Pearl and Prestige Awards • Chiller plant performance contract with SGBC accredited EPC firms. 	<p style="text-align: center;">2 points for high impact item</p> <p style="text-align: center;">1 point for medium impact item</p> <p style="text-align: center;">0.5 point for low impact item</p> <p style="text-align: center;">(Up to 10 Points)</p>
<p>PART 5 – OTHER GREEN FEATURES CATEGORY SCORE :</p>	<p>Sum of Green Mark Points obtained from ENRB 5-1</p>
<p>Green Mark Score (Existing Non-Residential)</p> <p>Green Mark Score = Σ Category Score [(Part 1 – Energy Efficiency) + (Part 2 – Water Efficiency) + (Part 3 – Sustainable Operation and Management) + (Part 4 – Indoor Environmental Quality) + (Part 5 – Other Green Features)]</p> <p>Where Category Score for Part 1 \geq 30 points and Σ Category score for Part 2, 3, 4 & 5 \geq 20 points</p>	

Annex 1: Maximum lighting power budget (including ballast loss)

Type of usage	Maximum lighting power budget (W/m ²)
Offices	15
Classrooms	15
Hotel guest room	15
Lecture theatres	15
Auditoriums / Concert halls	10
Shops / Supermarkets / Departmental stores (including general, accent & display lighting)	25
Restaurants	15
Lobbies / Atriums / Concourse	10
Stairs	10
Corridors	10
Car parks	5
Electronic manufacturing and fine detail / Assembly industries	20
Medium and heavy industries	15
Warehouses / Storage areas	10

7 DOCUMENTATION REQUIREMENTS

The details of the documentary evidences required can be found in the Appendix A: Scoring Methodology & Documentation for compliance. Building Owner, PE(Mech) and appropriate practitioners shall ensure that these documents and records are available as evidences to demonstrate compliance with the environmental sustainability standard and criteria.

Appendix A
SCORING METHODOLOGY & DOCUMENTATION

(I) Energy Related Requirements

Part 1 – Energy Efficiency

ENRB 1-1	Thermal Performance of Building Envelope
ENRB 1-2	Air Conditioning System
ENRB 1-3	Natural Ventilation / Mechanical Ventilation
ENRB 1-4	Artificial Lighting
ENRB 1-5	Ventilation in Car parks
ENRB 1-6	Ventilation in Common Areas
ENRB 1-7	Lifts and Escalators
ENRB 1-8	Energy Efficient Practices & Feature
ENRB 1-9	Energy Policy & Management
ENRB 1-10	Renewable Energy

ENRB 1-1 THERMAL PERFORMANCE OF BUILDING ENVELOPE

Objectives	Enhance overall thermal performance of building envelope to minimize heat gain thus reducing the overall cooling load requirement.
Applicability	Applicable to air-conditioned building spaces with aggregate areas > 500 m ² .
Baseline Standard	<p>ETTV stands for Envelope Thermal Transfer Value.</p> <p>Maximum permissible ETTV = 50 W/m²</p> <p>The computation of ETTV shall be based on the methodology specified in the Code on Envelope Thermal Performance for Buildings issued by BCA.</p>
Requirements	<p>Up to 5 points can be scored for building envelope with better thermal performance than the baseline standard :</p> <p>0.5 points for every reduction of 1 W/m² in ETTV from the baseline of 50W/m²</p> <p>Points scored = 0.5 x (50 – ETTV) where ETTV ≤ 50 W/m²</p> <p>For developments consisting of more than one building, the weighted average of the ETTVs based on the façade areas of these buildings shall be used as the basis for point allocation.</p> $ETTV_{\text{Weighted Average}} = \sum (ETTV_{\text{bldg}} \times A_{\text{bldg}}) / A_{\text{devt}}$ <p>where $ETTV_{\text{bldg}}$ = ETTV for a building (W/m²)</p> <p>A_{bldg} = Summation of all facade areas that enclose all the air-conditioning areas (m²) in a building</p> <p>A_{devt} = Summation of total applicable facade areas of all buildings within the development (m²) (i.e. $\sum A_{\text{bldg}}$)</p> <p><i>Note: For buildings that are underground, full 5 points will be given.</i></p>
Documentary Evidences	<ul style="list-style-type: none"> • Architectural elevation drawings showing the composition of the different façade or wall systems that are relevant for the computation of ETTV; • Architectural plan layouts and elevations showing all the air-conditioning areas; • Technical specifications of material showing the salient data of the material properties that were used for the façade or external wall system; and • ETTV calculation.
References	Code on Envelope Thermal Performance for Buildings (2008) issued by BCA.

**Worked
Example for
1-1**

Example 1

$$\text{ETTV} = 45 \text{ W/m}^2$$

$$\text{Points scored} = 0.5 \times (50 - \text{ETTV}) = 0.5 \times (50 - 45) = 2.5 \text{ points}$$

Example 2

$$\text{ETTV} = 35 \text{ W/m}^2$$

$$\text{Points scored} = 0.5 \times (50 - \text{ETTV}) = 0.5 \times (50 - 35) = 7.5 \text{ points} > 5 \text{ points}$$

Therefore, points scored should be 5 points (max)

Example 3

A proposed building development comprises three building blocks. The individual ETTV of the each building computed are as follows :

$$\begin{array}{l} \text{ETTV}_{\text{bldg1}} = 35 \text{ W/m}^2 \quad A_{\text{bldg}} = 5000 \text{ m}^2 \\ \text{ETTV}_{\text{bldg2}} = 45 \text{ W/m}^2 \quad A_{\text{bldg}} = 6800 \text{ m}^2 \\ \text{ETTV}_{\text{bldg3}} = 50 \text{ W/m}^2 \quad A_{\text{bldg}} = 7500 \text{ m}^2 \end{array} \left. \vphantom{\begin{array}{l} \text{ETTV}_{\text{bldg1}} \\ \text{ETTV}_{\text{bldg2}} \\ \text{ETTV}_{\text{bldg3}} \end{array}} \right\} \begin{array}{l} A_{\text{devt}} = 5000+6800+7500 \\ = 19300 \text{ m}^2 \end{array}$$

Therefore

$$\begin{aligned} \text{ETTV}_{\text{Weighted Average}} &= \sum (\text{ETTV}_{\text{bldg}} \times A_{\text{bldg}}) / A_{\text{devt}} \\ &= \frac{(\text{ETTV}_{\text{bldg1}} \times A_{\text{bldg1}}) + (\text{ETTV}_{\text{bldg2}} \times A_{\text{bldg2}}) + (\text{ETTV}_{\text{bldg3}} \times A_{\text{bldg3}})}{(A_{\text{devt}})} \\ &= \frac{(35 \times 5000) + (45 \times 6800) + (50 \times 7500)}{19300} \\ &= 44.35 \text{ W/m}^2 \end{aligned}$$

$$\text{Points scored} = 0.5 \times (50 - \text{ETTV}) = 0.5 \times (50 - 44.35) = 2.83 \text{ points}$$

Note : Refer to the Code on Envelope Thermal Performance for Buildings for more detailed examples on how to compute the ETTV.

ENRB 1-2 AIR-CONDITIONING SYSTEM

<p>Objectives</p>	<p>Encourage the use of better energy efficient air-conditioned equipments to minimize energy consumption.</p>																				
<p>Applicability</p>	<p>Applicable to air-conditioned building areas where its aggregate air-conditioned areas > 500 m².</p> <p>Scope covers all air-conditioned equipments for the buildings as listed:</p> <ul style="list-style-type: none"> ▪ Chillers ▪ Chilled-Water Pumps ▪ Condenser Water Pumps ▪ Cooling Towers ▪ Air Handling Units (AHUs) ▪ Fan Coil Units (FCU) ▪ Direct-Expansion (DX) Unitary Air-Conditioners / Condensing Units which include single-split units, multi-split units and variable refrigerant flow (VRF) system 																				
<p>Baseline Standard</p>	<p><u>1-2(a) Water Cooled Chilled-Water Plant</u></p> <table border="1" data-bbox="395 969 1442 1167"> <thead> <tr> <th rowspan="2">Baseline</th> <th colspan="2">Building Cooling Load</th> </tr> <tr> <th>< 500 RT</th> <th>≥ 500 RT</th> </tr> </thead> <tbody> <tr> <td><u>Pre-requisite Requirements</u> Minimum System Efficiency for Water-cooled Chilled Water Plant</td> <td>0.85 kW/RT</td> <td>0.75 kW/RT</td> </tr> </tbody> </table> <p><u>1-2(b) Air Cooled Chilled-Water Plant/ Unitary Air-Conditioners</u></p> <table border="1" data-bbox="395 1317 1442 1547"> <thead> <tr> <th rowspan="2">Baseline</th> <th colspan="2">Building Cooling Load</th> </tr> <tr> <th>< 500 RT</th> <th>≥ 500 RT</th> </tr> </thead> <tbody> <tr> <td><u>Pre-requisite Requirements</u> Minimum System Efficiency for Air Cooled Chilled-Water Plant or Unitary Air-Conditioners</td> <td>1.1 kW/RT</td> <td>1.0 kW/RT</td> </tr> </tbody> </table> <p><u>1-2(c) Air Distribution System</u></p> <p>For air distribution fan systems, the fan motor power required shall not exceed the baseline as shown in the table below.</p> <table border="1" data-bbox="395 1783 1402 1877"> <thead> <tr> <th>Constant Air Volume System</th> <th>Variable Air Volume System</th> </tr> </thead> <tbody> <tr> <td>0.47 W/cmh</td> <td>0.74 W/cmh</td> </tr> </tbody> </table>	Baseline	Building Cooling Load		< 500 RT	≥ 500 RT	<u>Pre-requisite Requirements</u> Minimum System Efficiency for Water-cooled Chilled Water Plant	0.85 kW/RT	0.75 kW/RT	Baseline	Building Cooling Load		< 500 RT	≥ 500 RT	<u>Pre-requisite Requirements</u> Minimum System Efficiency for Air Cooled Chilled-Water Plant or Unitary Air-Conditioners	1.1 kW/RT	1.0 kW/RT	Constant Air Volume System	Variable Air Volume System	0.47 W/cmh	0.74 W/cmh
Baseline	Building Cooling Load																				
	< 500 RT	≥ 500 RT																			
<u>Pre-requisite Requirements</u> Minimum System Efficiency for Water-cooled Chilled Water Plant	0.85 kW/RT	0.75 kW/RT																			
Baseline	Building Cooling Load																				
	< 500 RT	≥ 500 RT																			
<u>Pre-requisite Requirements</u> Minimum System Efficiency for Air Cooled Chilled-Water Plant or Unitary Air-Conditioners	1.1 kW/RT	1.0 kW/RT																			
Constant Air Volume System	Variable Air Volume System																				
0.47 W/cmh	0.74 W/cmh																				

**Requirements
for 1-2(a) &
1-2(b)**

1-2 (a) Water Cooled Chilled-Water Plant (Up to 20 points)

Building cooling load \geq 500 RT

- 14 points for achieving chiller plant efficiency of 0.75 kW/RT.
- 0.35 point for every percentage improvement in the chiller plant efficiency better than 0.75 kW/RT.
- Points scored = 0.35 x (% improvement)

Building cooling load < 500 RT

- 14 points for achieving chiller plant efficiency of 0.85 kW/RT.
- 0.3 point for every percentage improvement in the chiller plant efficiency better than 0.85 kW/RT.
- Points scored = 0.3 x (% improvement)

1-2 (b) Air Cooled Chilled-Water Plant

Building cooling load \geq 500 RT

- 14 points for achieving chiller plant efficiency of 1.0 kW/RT.
- 0.25 points for every percentage improvement in the air-conditioning system efficiency better than 1.0 kW/RT.
- Points awarded = 0.25 x (% improvement)

Building cooling load < 500 RT

- 14 points for achieving chiller plant efficiency of 1.1 kW/RT.
- 0.2 point for every percentage improvement in the air-conditioning system efficiency better than 1.1 kW/RT.
- Points awarded = 0.2 x (% improvement)

Important notes :

- (i) Where there is a combination of central chilled-water plant with unitary air-conditioned system, the computation for the points scored will only be based on the air-conditioning system with a larger aggregate capacity.
- (ii) The building cooling load and chiller plant system efficiency can be determined based on the measured operating conditions of the system; which shall include the chillers, pumps, cooling towers and associated equipment.
- (iii) For simplicity and consistency, the expected operating efficiency will be based on the total energy consumption over total hourly cooling loads during the specified building operation hours as defined below :

Office Buildings:

- Monday to Friday : 9 am to 6 pm

Retail Malls :

- Monday to Sunday : 10 am to 9 pm

Hotels and serviced apartments :

- Monday to Sunday : 24 Hours
(day time load: 7am to 11pm; night time load: 11pm to 7am)

Other Building Types

To be determined based on operating hours

- (iv) For the design system efficiency, the expected chilled water plant efficiency shall be calculated based on the measured building cooling load profile through an Energy Audit before the retrofit. The energy audit shall be performed by an accredited Energy Services Company (ESCO) or a Professional Mechanical Engineer (Mech).
- (v) For air-cooled variable refrigerant flow system and unitary air-conditioners, the efficiency shall be computed based on the efficiency of rated capacity or at the expected operating part-load condition of the outdoor condensing units.

1-2 (c) Air Distribution System (Up to 8 points)

- 0.15 point for every percentage improvement in the air distribution system efficiency above the baseline.

Constant Air Volume System	Variable Air Volume System
0.47 W/cmh	0.74 W/cmh

Points scored = 0.15 x (% improvement)

- The efficiency of the air distribution system can be determined from the rated fan power and air flowrate of the AHU and FCU or by site measurement.

1-2 (d) Instrumentation for Monitoring Central Chilled Water Plant Efficiency

- 1 point for the provision of permanent measuring instruments for monitoring of water-cooled and air-cooled chilled-water plant efficiency. The installed instrumentation shall have the capability to calculate resultant chilled-water plant efficiency (i.e. kW/RT) within $\pm 5\%$ of the true value and in accordance with ASHRAE Guide 22 and AHRI 550/590.

Requirements for 1-2(c)

Requirements for 1-2(d)

- The following instrumentation and installation are also required to be complied with :
 - (a) Location and installation of the measuring devices to meet the manufacturer's recommendation.
 - (b) Data Acquisition system i.e. Analog-to-digital or A/D converter used shall have a minimum resolution of 16 bit. For example,
 - The specification for the A/D converter of the BTU meter should have a minimum resolution of 16-bit. This applies to direct data acquisition from the BTU meter.
 - For data acquisition using Building Management System (BMS), the specification of the specific Digital Direct Controller (DDC) connecting the temperature sensors should have a minimum resolution of 16-bit.
 - (c) All data logging with capability to trend at 1 minute sampling time interval.
 - (d) Flow meters for chilled-water and condenser water loop shall be ultrasonic / full bore magnetic type or equivalent.
 - (e) Temperature sensors are to be provided for chilled water and condenser water loop and the measurement system shall have an end-to-end uncertainty from the temperature sensors to the read out devices not exceeding ± 0.05 °C over the entire measurement or calibration range. All thermo-wells shall be installed in a manner that ensures that the sensors can be in direct contact with fluid flow.
 - (f) Provisions shall be made for each temperature measurement location to have two spare thermo-wells located at both side of the temperature sensor for verification of measurement accuracy.
 - (g) Dedicated digital power meters shall be provided for the following groups of equipment: chiller(s), chilled water pump(s), condenser water pump(s) and cooling tower fan(s).

1-2 (e) Heat balance Substantiating test

1 point for submitting the verification of chilled-water plant instrument using the heat balance-substantiating test in accordance with AHRI 550/590. The heat balance shall be computed over the entire normal operating hours with more than 80% of the computed heat balance within $\pm 5\%$ over a one (1) week period.

For a perfectly balanced chiller system, the heat balance is represented by the following equation:

$$q_{\text{condenser}} = q_{\text{evaporator}} + W_{\text{input}}$$


where $q_{\text{condenser}}$ = heat rejected

$q_{\text{evaporator}}$ = cooling load

W_{input} = power input to compressor

The pressure enthalpy diagram below shows the concept of heat balance equation in a vapour compression cycle.

Requirements for 1-2(e)



Pressure Enthalpy Chart

The system heat balance of the chilled water plant shall be computed using the formula stated below over the normal operating hours,

$$\text{Percent Heat Balance} = \left| \frac{(q_{\text{evaporator}} + W_{\text{input}}) - q_{\text{condenser}}}{q_{\text{condenser}}} \right| \times 100\% \leq 5\%$$

Note: For open drive chillers, the W_{input} shall take into account the motor efficiency provided by the manufacturer. An example is provided as follows:

Input power to motor = 100kW (measured)

Motor rated efficiency (η) = 90%

Adjusted power input to compressor W_{input} = 100kW x 90%
= 90kW

In the event where hydraulic losses of pumps constitute a substantial heat gain, these losses could be accounted for. The values shall be determined from motor efficiency and pump efficiency values provided by the manufacturer. Examples are illustrated as follows:

(a) **For chilled water pump(s) adjustment,**

Motor input power (measured) = 30 kW (A)

Motor rated efficiency (η) = 90% (B)

Pump rated efficiency (η) = 80% (C)

Hydraulic losses = (A) x (B) x [(100% - (C))]
= 30kW x 90% x (100% - 80%)
= 5.4 kW

Adjusted total input power W_{input} = kW_i (chillers) + 5.4kW

where kW_i (chillers) = adjusted power input to compressor, kW

ID	Description	Name plate motor (kW)	Pump Head (m)	Flow rate (L/S)	Pump / Fan efficiency	Motor Efficiency
CHWP-1	Chilled water pump 1	55 kW	30m	151.2	85%	95%
CHWP-2	Chilled water pump 2	30 kW	30m	75.6	85%	95%
CWP-1	Condenser water pump 1	45 kW	20m	189	85%	95%
CWP-2	Condenser water pump 2	22 kW	20m	94.5	85%	95%
CT-1	Cooling tower 1	45 kW	-	130	75%	92%
CT-2	Cooling tower 2	45 kW	-	130	75%	92%

ID	Description	Type	Name plate motor (kW)	Cooling Capacity (RT)	Chilled water LWT	Chilled water ΔT	Efficiency kW/RT
CH-1	Chiller 1	Centrifugal	550	1000	6.7 °C	5.5°C	0.55
CH-2	Chiller 2	VSD Screw	260	500	6.7 °C	5.5°C	0.52

Documentary Evidences for 1-2(c)

For 1-2(c) – Air Distribution System

- Detailed calculations of the overall improvement in equipment efficiency of the air distribution system in the prescribed tabulated formats as shown in the worked examples 1-2(c);
- Technical product information of the air distribution system.

Documentary Evidences for 1-2(d)

For 1-2(d) – Permanent Measuring Instrument

- Instruments' calibration certificates from accredited laboratory and factory calibration certificates from manufacturers.
- Design / As-built drawings of the chiller plant room layouts showing the details of the instruments' locations.
- Summary of instruments to be presented in the following format :-

ID	Description	Sensor Type	Measurement/ Calibration range	Measurement Uncertainty	Last Calibration Date
TT01	CHWS Temperature	10K Ω Thermistor	0°C - 40°C	$\pm 0.05^\circ\text{C}$	10/10/2012
TT02	CHWR Temperature	10K Ω Thermistor	0°C - 40°C	$\pm 0.05^\circ\text{C}$	10/10/2012
TT03	CWS Temperature	10K Ω Thermistor	0°C - 40°C	$\pm 0.05^\circ\text{C}$	10/10/2012

	TT04	CWR Temperature	10K Ω Thermistor	0°C - 40°C	$\pm 0.05^\circ\text{C}$	10/10/2012
	FM01	CHW Flow	Magnetic Full Bore	30 l/s- 200 l/s	$\pm 0.5\%$	10/10/2012
	FM02	CW Flow	Magnetic Full Bore	30 l/s- 200 l/s	$\pm 0.5\%$	10/10/2012
	kW01	Chiller 1 Power	True RMS, 3 phase	60 – 600 kW	$\pm 0.5\%$	10/10/2012
	kW02	Chiller 2 Power	True RMS, 3 phase	60 – 600 kW	$\pm 0.5\%$	10/10/2012
	kW03	CHW Pump 1 & 2 Power	True RMS, 3 phase	20 – 200 kW	$\pm 0.5\%$	10/10/2012
	kW04	CW Pump 1 & 2 Power	True RMS, 3 phase	20 – 200 kW	$\pm 0.5\%$	10/10/2012
	kW05	CT 1 & 2 Power	True RMS, 3 phase	15 – 150 kW	$\pm 0.5\%$	10/10/2012
Documentary Evidences for 1-2(e)	<ul style="list-style-type: none"> • Calculation of the overall uncertainty of measurement of the resultant chiller plant efficiency in kW/RT to be within $\pm 5\%$ of the true value based on instrumentation specification / calibration certificates. Refer to Worked examples 1-2(d). 					
	<p><u>For 1-2(e) – Heat Balance Substantiating Test</u></p> <ul style="list-style-type: none"> • Heat balance substantiating test result verifying the central chilled-water plant's instrumentation shall be submitted in the format as specified in the Worked Examples for 1-2(e). 					
	Documentary Evidences for 1-2(f)	<p><u>For 1-2 (f) – Variable Speed Drives</u></p> <ul style="list-style-type: none"> • Technical specifications of the control devices and a write up/drawings on how these devices are used; • Plan layouts showing the locations of variable speed control devices for the chiller plant equipment i.e. chilled water pump and cooling tower fans; or schematic print-out from BMS; 				
Documentary Evidences for 1-2(g)		<p><u>For 1-2(g) – Sensors for Carbon Dioxide</u></p> <ul style="list-style-type: none"> • Technical specifications of the control devices and a write up/drawings on how these devices are used; • Plan layouts showing the locations and the types of control devices used to regulate fresh air intake or schematic print-out from BMS. 				
	References	<p>CP 24:1999 - Code of Practice for Energy Efficiency Standard for Building Services and Equipment</p> <p>CP 13:1999 - Code of Practice for Mechanical ventilation and Air-Conditioning in Buildings</p> <p>ASHRAE Guideline 22 – Instrumentation for Monitoring Central Chilled water Plant Efficiency by American Society of Heating, Refrigerating and Air-Conditioning Engineer (ASHRAE)</p>				

	<p>AHRI Standard 550/590 – Performance Rating of Water Chilling and Heat Pump Water–Heating Packages Using the Vapour Compression Cycle by Air-Conditioning, Heating and Refrigeration Institute(AHRI)</p> <p>Singapore Standard 591 (2013) – Code of Practice for long term measurement of central chilled water system energy efficiency</p>
--	--

Worked Examples for 1-2(a)


Determining the System Efficiency for Central water-cooled chiller system

Background info

- Office building air-conditioned floor area = 70,000 m²
- Building operating hours : 8 am to 6pm
- The building cooling load profile is determined from the energy audit on the chiller plant before retrofitting; the result is shown below.

Step 1 : Building cooling load profile (from audit measurements)

Based on the measured building cooling load profile for the building operation hours from 8:00 to 18:00, the cooling load is **1200 RT**.



**Worked
Examples for
1-2(a)**

Continued

From energy audit, the building cooling load profile is shown:-

Time	Average Cooling Load (RT)
0:00	190
1:00	190
2:00	190
3:00	190
4:00	190
5:00	190
6:00	190
7:00	1400
8:00	1200
9:00	1200
10:00	1200
11:00	1200
12:00	1200
13:00	1200
14:00	1200
15:00	1200
16:00	1150
17:00	1150
18:00	1150
19:00	190
20:00	190
21:00	190
22:00	190
23:00	190

The chiller plant system efficiency will be computed based on the following cooling loads measured during the specified operating hours i.e. 0900 to 1800 hrs (office building):

- (a) 0900 to 1600 hrs : 1200 RT
- (b) 1600 to 1800 hrs : 1150 RT

Worked Examples for 1-2(a)

Continued

Step 2 : Proposed Chiller Plant Equipment configuration

Proposed chiller plant equipment configuration:-

Equipment	Office hours (0900 to 1800 hrs)	After Office hours (1800 to 0900 hrs)
Chillers	3 nos. x 700 RT (2 in operation & 1 stand-by)	2 nos. x 200 RT (1 in operation & 1 stand-by)
Chilled Water Pumps	3 nos. x 45 kW (2 in operation & 1 stand-by)	2 nos. x 15 kW (1 in operation & 1 stand-by)
Condenser Water Pumps	3 nos. x 55 kW (2 in operation & 1 stand-by)	2 nos. x 18.5 kW (1 in operation & 1 stand-by)
Cooling Towers	3 nos. x 900 RT, each having 3 fans x 7.5 kW	

Important notes :

- (1) It is important to design the air-conditioning plant configuration for other load conditions that are not within the building operating hours specified, although this is not required for point scoring purpose.
- (2) The estimated operating pump and motor power of the various components at part-load condition as illustrated in Step 4 & 5 are based on the affinity laws assuming that the system curve remains unchanged.

Step 3 : Water-cooled Chillers' Performance

Chillers in operation are 2 nos. x 700 RT during office hours and 1 no. x 200 RT for after office hour operation.

Performance data for selected chillers (700 RT) as given by chiller suppliers is shown below:-

% Load	Capacity (RT)	Chiller Input Power (kW)	Chiller Efficiency kW/RT	Evaporator		Condenser	
				CHWST (°C)	CHWRT (°C)	CWRT (°C)	CWST (°C)
100	700	363	0.519	6.67	12.31	34.80	29.68
90	630	329	0.522	6.67	12.31	34.29	29.68
80	560	291	0.520	6.67	12.31	33.78	29.68
70	490	260	0.533	6.67	12.31	33.28	29.68
60	420	227	0.543	6.67	12.31	32.77	29.68
50	350	195	0.563	6.67	12.31	32.27	29.68
40	280	165	0.596	6.67	12.31	31.76	29.68
30	210	135	0.652	6.67	12.04	31.25	29.68
20	140	104	0.750	6.67	10.27	30.75	29.68
15	105.3	87	0.836	6.67	9.39	30.50	29.68

Cooling load (RT)	No. of Chillers in operation	% Load	kW/RT	Total Chiller Power (kW)
A	B	C	D	E = A x D
1200 RT	2 nos. x 700RT	85.7%	0.521	625.2
1150 RT	2 nos. x 700RT	82.1%	0.520	598.0

Worked Examples for 1-2(a)

Continued

Step 4 : Chilled Water Pumps' Performance

- (i) 2 nos. x 45 kW pumps will be in operation during office hours and are installed with Variable Speed Drives (VSD)
- (ii) Operating pump head = 28 m (from energy audit)
- (iii) Pump efficiency = 86.8 % at design operation condition
- (iv) Motor efficiency = 94.2 % at design operation condition
- (v) Motor absorbed power (kW) is calculated from = $\frac{(Q)(\rho)(g)(h)}{(10^6)(\eta_p)(\eta_m)}$

where

Q=water flow rate in L/s
 ρ=density of water = 1000 kg/m³
 g=gravitational acceleration = 9.81 m/s²
 h=static pressure head m
 η_p= pump efficiency
 η_m=motor efficiency

Chilled Water Pump 1 & 2 (45 kW)					
% Load	A	B	C	D	E = (A x 1000 x 9.81 x B) / (10 ⁶ x C x D)
	Rated Flow (l/s)	Rated Head (m)	Motor Efficiency (%)	Pump Efficiency (%)	Pump input power (kW)
100	106.1	28	94.2	86.8	35.64
90	95.49	22.68	94.2	84.2	26.76
85.7	90.9	20.56	94.2	84	23.17
82.1	87.1	18.87	94.2	83.7	20.45
80	84.88	17.92	94.2	83.3	19.00
70	74.27	13.72	94.2	79.9	13.27
60	63.66	10.08	94.2	77.3	8.64

For total cooling requirement of 1200 RT, the 2 nos. CHW pumps will operate at part-load i.e. 1200RT / 1400RT i.e. 85.7%.

Cooling load (RT)	No. of CHW pumps in operation	% Load	Pump input power (kW)	Total CHW Pump Power (kW)
A	B	C	D	E = B x D
1200	2 nos.	85.7%	23.17	46.34
1150	2 nos.	82.1%	20.45	40.9

Note: It is recommended to limit the speed of the pump to a minimum of 60% of the load.

Worked Examples for 1-2(a)

Continued

Step 5 : Condenser Water Pumps' Performance

- (i) 2 nos. x 55 kW will be in operation during office hours and all pumps are installed with Variable Speed Drives (VSD)
- (ii) Operating pump head = 32 m (from energy audit)
- (iii) Pump efficiency = 88.5 % at design operation condition
- (iv) Motor efficiency = 94.7 % at design operation condition

Condenser Water Pump 1 & 2 (55 kW)					
% Load	A	B	C	D	$E = (A \times 1000 \times 9.81 \times B) / (10^6 \times C \times D)$
	Rated Flow (L/s)	Rated Head (m)	Motor Efficiency (%)	Pump Efficiency (%)	Pump input power (kW)
100	132.51	32	94.7	88.5	49.63
90	119.26	25.92	94.7	85.9	37.28
85.7	113.56	23.5	94.7	85.5	32.33
82.1	108.8	21.57	94.7	85.2	28.53
80	106.01	20.48	94.7	85	26.46
70	92.76	15.68	94.7	81.4	18.51
60	79.51	11.52	94.7	78.8	12.04

The 2 nos. CW pumps are designed to operate consistently at part-load condition 85.7%

Cooling load (RT)	No. of CW pumps in operation	% Load	Pump input power (kW)	Total CW Pump Power (kW)
A	B	C	D	E = B x D
1200	2 nos.	85.7%	32.33	64.66
1150	2 nos.	85.7%	32.33	64.66

Note: It is recommended to limit the speed of the pump to a minimum 60% of the rated capacity.

Worked Examples for 1-2(a)

Continued

Step 6 : Operating efficiency for Cooling Towers

- (i) 2 nos. cooling towers will be in operation with Variable Speed Drives (VSD)
- (ii) Heat rejection capacity per cooling tower = 900 RT
- (iii) Total heat rejection for 2 nos. cooling towers = 900 RT x 2 = 1800 RT
- (iv) Each tower with 3 fan cells, each fan motor = 7.5 kW
- (v) Fan Motor efficiency = 92 %
- (vi) Fan motor input power for each tower = (7.5 kW x 3 fans.) / 92% = 24.46 kW
- (vii) Total power for 2 nos. cooling towers = 24.46 kW x 2 = 48.92 kW

Cooling load (RT)	Chiller Input Power (kW)	Required Heat Rejection (RT)
A	B	C = A + (B / 3.517)
1200	625.2	1377.77
1150	598	1320.03

Cooling load (RT)	No. of CT in operation	Total CT Heat Rejection Capacity (RT)	Percentage Loading for Required & Available Heat Rejection (RT)
A	B	D	E = C / D
1200	2	1800	76.5 %
1150	2	1800	73.3 %

At full speed (100%), total cooling tower (2 nos.) power consumption = 24.46 x 2 = 48.92 kW

Based on the fan law,

$$\frac{\text{Fans Power}_{@ 76.6\%}}{\text{Fans Power}_{@ 100\%}} = \left(\frac{\text{Fans Speed}_{@ 76.6\%}}{\text{Fans Speed}_{@ 100\%}} \right)^3$$

At 76.6% speed (via VSD), total cooling towers' fans power = 48.92 x (0.765)³ = **21.90 kW**

Similarly, at 73.4% speed, total cooling towers' fans power = 48.92 x (0.733)³ = **19.27 kW**

Cooling Load (RT)	Required Part load % for CT	Total Fan Motor Power at required part load (kW)
1200 RT	76.5%	21.90
1150 RT	73.3%	19.27

Note: It is recommended to limit the speed of the cooling tower fans to a minimum of 50% of the rated capacity.

Step 7 : System Efficiency

The chiller plant system efficiency at various cooling loads is tabulated below.

Time	Average Cooling Load	Chillers Power Input	CHW Pumps Power	CW Pumps Power	CT power	Total Power Input
	(RT)	(kW)	(kW)	(kW)	(kW)	(kW)
9:00	1200	625.2	46.34	64.66	21.90	758.1
10:00	1200	625.2	46.34	64.66	21.90	758.1
11:00	1200	625.2	46.34	64.66	21.90	758.1
12:00	1200	625.2	46.34	64.66	21.90	758.1
13:00	1200	625.2	46.34	64.66	21.90	758.1
14:00	1200	625.2	46.34	64.66	21.90	758.1
15:00	1200	625.2	46.34	64.66	21.90	758.1
16:00	1150	598	40.9	64.66	19.27	722.83
17:00	1150	598	40.9	64.66	19.27	722.83
18:00	1150	598	40.9	64.66	19.27	722.83
Total (0900 to 1800)	$\sum CL_i = 11850$	6170.4	447.08	646.6	211.11	$\sum TPL_i = 7475.19$
Efficiency kW/RT		0.521	0.038	0.055	0.018	0.631

To summarize, the chiller plant system efficiency for this office building is :

Equipment	Efficiency (kW/RT)
Chillers	0.521
Chilled water pumps	0.038
Condenser water pumps	0.055
Cooling towers	0.018
Total	0.631

< 0.75 kW/RT

14 points for meeting the prescribed chilled-water plant efficiency of 0.75 kW/RT

0.35 point for every percentage improvement in the chilled-water plant efficiency over the baseline

$$\begin{aligned}
 \text{Therefore, points scored} &= 14 + 0.35 \times (\% \text{ improvement}) \\
 &= 14 + 0.35 \times [(0.75 - 0.631)/0.75] \times 100 \\
 &= 14 + 0.35 (15.89) \\
 &= 19.56 \text{ points}
 \end{aligned}$$

Worked Examples for 1-2(b)

VRF System

Determining the System Efficiency for Unitary Air-Conditioners/ Condensing Units - VRF System For total cooling load < 500RT

Method (A): Computation of system efficiency based on the rated capacity
 Determine the overall efficiency of the VRF system at full load conditions:

Floor	Location Served	Specification of VRF Outdoor Condensing Unit		
		Total Cooling Capacity (kW)	Rated Power Input (kW)	COP
1	FCC Room	3.5	1.25	2.8
	Lift Lobby + Corridor	22.4	5.24	4.27
	Reception			
2	Office	44.8	10.5	4.27
	Office	44.8	10.5	4.27
	Lift lobby + Corridor	22.4	5.24	4.27
3	Office	44.8	10.5	4.27
	Office	44.8	10.5	4.27
	Lift lobby + Corridor	22.4	5.24	4.27
4	Office	44.8	10.5	4.27
	Office	44.8	10.5	4.27
	Lift lobby + Corridor	22.4	5.24	4.27
5	Office	63.3	18.4	3.44
	Lift lobby + Corridor	22.4	5.24	4.27
Total		447.6 kW	108.85	

The total installed capacity of the VRF system = 447.6 kW

Assume building cooling load = **127.3 RT**

Overall efficiency for the VRF system at full load condition = $108.85 / 127.3$
 = **0.86 kW/RT**

For Building cooling load < 500 RT, 14 points for achieving chiller plant efficiency of 1.1 kW/RT.

0.2 point for every percentage improvement in the air-conditioning system efficiency better than 1.1 kW/RT.


$$\begin{aligned}
 \text{Therefore, points scored} &= 14 + 0.2 \times (\% \text{ improvement}) \\
 &= 14 + 0.2 \times [(1.1 - 0.86) / 1.1] \times 100 \\
 &= 14 + 0.2 \times (21.82) \\
 &= 18.36 \text{ points}
 \end{aligned}$$

Method(B): Computation of the system efficiency based on the expected operating part load condition

Step B-1 Determine the most frequent occurring operating part load condition of the installed outdoor condensing unit capacity for all zones

(Most frequent occurring operating part-load conditions can be determined by the operating load points that form a horizontal straight line; the points can either fall on the line or very close to the line)


B-1(a) Zone 1 design day cooling load profile:



Time	Cooling Load (kW)
0:00 – 7:00	0
8:00	18.5
9:00	21.5
10:00	14.2
11:00	14.1
12:00	17.6
13:00	15.5
14:00	14.1
15:00	13.6
16:00	13.4
17:00	13.7
18:00	14.3
19:00	17.9
20:00–23:00	0

Based on the simulated building cooling load profile for the building operation hours from 8:00 to 19:00, the estimated most frequent occurring part-load condition of the installed capacity is 60% i.e. 13.4 kW for Zone 1

B-1 (b) Zone 2 to 10 design day cooling load profile.



Based on the simulated building cooling load profile for the building operation hours from 8:00 to 19:00, the estimated most frequent occurring part-load condition of the installed capacity is 70%
i.e. 31.4 kW for Zone 2 to 9

Time	Cooling Load (kW)
0:00 – 7:00	0
8:00	33.5
9:00	32.9
10:00	31.0
11:00	31.3
12:00	26.5
13:00	31.1
14:00	32.4
15:00	39.0
16:00	31.5
17:00	30.5
18:00	30.2
19:00	25.9
20:00–23:00	0

Step B-2 Proposed VRF System Schedule

System	Floor	Location Served	Specification of VRF Outdoor Condensing Unit						
			Total Cooling Capacity (kW)		Power Input (kW)		COP		KW/RT
			Full Installed Capacity	60% Part load	Full Installed Capacity	60% Part load	Full Installed Capacity	60% Part load	60% Part load
1	1	FCC Room	22.4	13.4	5.24	2.55	4.2	5.25	0.67
	1	Lift Lobby + Internal Corridor							
	1	Reception							
System	Floor	Location Served	Full Installed Capacity	70% Part Load	Full Installed Capacity	70% Part Load	Full Installed Capacity	70% Part Load	70% Part Load
2 to 9	2 to 9	Office	44.8	31.4	10.5	6.28	4.29	5.02	0.70
		Office							
		Office							
		Office							
		Office							
		Lift Lobby							
		Lobby 2							

Step B-3 Determine the system efficiency of the VRF systems at the expected operating part-load condition

The system efficiency of VRF systems serving the building is:

System	Floor	Total Power Input (kW)	Total Required Cooling (kW)	Total Required Cooling (RT)
1	1	2.55	13.4	3.81
2 to 9	2 to 9	50.24	251.2	71.42
Total:		52.79		75.23

System efficiency for the VRF system = 52.79 / 75.23

= 0.70 kW/RT

14 points for meeting the prescribed system efficiency of 1.1 kW/RT

0.6 points for every percentage improvement in the air-conditioning system efficiency over the baseline

Points scored = 14 + 0.2 x (% improvement)

= 14 + 0.2 [(1.1 – 0.70)/1.1 x 100%] = 21.27 points > 20 points

Therefore, points scored is 20 points (max)

Worked Examples for 1-2(c)

For 1-2(c) - Determining the Efficiency for Air Distribution Equipment from Technical Specification / Nameplates

1. AHUs (VAV system):
 - a. Total fan power consumption = 245.527 kW = 245527 W
 - b. Total air volume flow rate = 409212 CMH

Air-side system efficiency = 245527/409212 = 0.6 W/CMH

2. AHUs (CAV system):
 - a. Total fan power consumption = 275.2 kW = 275200 W
 - b. Total air volume flow rate = 678520 CMH

Air-side system efficiency = 275200/678520 = 0.406 W/CMH

3. FCUs
 - a. Total fan power consumption = 411.52 kW = 411520 W
 - b. Total air volume flow rate = 979805 CMH

Air-side system efficiency = 411520/979805 = 0.420 W/CMH

4. Overall required air distribution system efficiency specified under CP 13:1999

$$= \frac{(0.74)(409212) + (0.47)(678520) + (0.47)(979805)}{(409212 + 678520 + 979805)} = 0.523 \text{ W/CMH}$$

5. Overall required air distribution system efficiency based on suppliers' specs / contract specs = (245527 + 275200 + 411520) / (409212 + 678520 + 979805)

$$= 932247/2067537 \text{ W/CMH}$$

$$= 0.451 \text{ W/CMH}$$

Table 1-2(c) : Equipment Efficiency (Air-Distribution System)

Equipment Type	From Specs		Allowable nameplate motor power CP 13 (W/CMH)	Power Required by the motor at design condition (W/CMH)
	Total air flow (CMH)	Nameplate motor power (W)		
1. AHUs (VAV)	409212	245527	0.74	0.60
2. AHUs (CAV)	678520	275200	0.47	0.406
3. FCUs	979805	411520	0.47	0.420
Total	2067537	932247	0.523	0.451

See working (4) above

See working (5) above

$$\begin{aligned} \text{\% Improvement in Efficiency for Air Distribution Equipment} &= (0.523 - 0.451) / 0.523 \\ &= 0.1377 \times 100\% \\ &= 13.77\% \end{aligned}$$

$$\text{Points scored} = 0.2 \times (\% \text{ improvement}) = 0.2 \times (13.77) = 2.75 \text{ points}$$

Worked Examples For 1-2(d)

Computation of overall uncertainty in the resulting chilled-water plant efficiency

For 1-2(d) - Computation of overall uncertainty in the resulting chilled-water plant efficiency

As instrumentation measurement uncertainties stated in calibration certificates and technical specifications are based on controlled conditions in a laboratory, it is necessary to allow for on-site deviations and measurements. The overall measurement system comprising the temperature, flow and power measurement shall be capable of calculating resultant chiller-water plant efficiency with the uncertainty within ±5% for on-site measurement. Each measurement shall include the sensor, any signal conditioning (if available), the data acquisition system and the wiring connecting them. The following example illustrates the computation of the uncertainty of the overall measurement system installed.

Item	Measurement System	End-to-End Measurement Uncertainty (% of reading)
1	Temperature	$\frac{\sqrt{0.05^2 + 0.05^2}}{5.5} = 1.3\%$ see note (1)
2	Flow	1% see note (2) + 1% (i.e. 2%)
3	Power	1% see note (3)

Note:

(1) Temperature measurement system shall have an end-to-end measurement uncertainty of ± 0.05°C over the entire measurement range. The combined uncertainty for ΔT is computed based on the root-sum square formula with ΔT assumed to be 5.5 °C as illustrated above.

(2) An additional 1% to be included in the computation of measurement errors for flow meter.

(3) Uncertainty of power measurement system shall include that of the current transformer where applicable. It is recommended that 3rd party verified power meter be specified to ensure accuracy.

The overall uncertainty of the measurement system shall be the combination of the individual uncertainty of each measurement system. Based on the above information, the overall uncertainty of measurement is as shown in the following :

$$\begin{aligned}
 \text{Error}_{\text{rms}} &= \sqrt{(\sum U_N)^2} && \text{where } U_N = \text{individual uncertainty of variable N (\%)} \\
 &= \sqrt{(1.3^2 + 2^2 + 1^2)} && N = \text{mass flow rate, electrical power input or delta T} \\
 &= 2.6 \%
 \end{aligned}$$

Therefore, the total uncertainty for the calculated chilled-water plant efficiency (kW/RT) is 2.6 %, which falls within the 5% of the true value.


Worked Example 1-2(e)

Determining Heat Balance for Different Plant Configuration

Constant Primary Chilled Water System

Determining Heat Balance for Different Plant Configurations

Plant A – Constant Primary Chilled-Water System



A: $q_{\text{evaporator}} = m \times C_p \times \Delta T = FM1 \times C_p \times (CHWR - CHWS)$

B: $q_{\text{condenser}} = m \times C_p \times \Delta T = FM2 \times C_p \times (CWR - CWS)$

C: $W_{\text{input}} = kW_{i-1} + kW_{i-2} + kW_{i-3}$

where $C_p = 4.19 \text{ kJ/kg} \cdot ^\circ\text{C}$ & density of chilled water is assumed to be 1 kg/l

Percent heat balance = $[(A + C) - B] / B \times 100\%$

Note : In the event where hydraulic losses of pumps constitute substantial heat gain, $W_{\text{input}}/ q_{\text{condenser}}$ may be adjusted to account for these additional heat gain. The value shall be determined from variable speed drive losses, motor efficiency and pump efficiency values certified by the manufacturer.


Worked Example 1-2(e)

Determining Heat Balance for Different Plant Configuration

Variable Primary Chilled Water System

Determining Heat Balance for Different Plant Configuration

Plant B – Variable Primary Chilled-Water System



A: $q_{\text{evaporator}} = \text{FM1} \times C_p \times (\text{CHWR} - \text{CHWS})$
 B: $q_{\text{condenser}} = \text{FM2} \times C_p \times (\text{CWR} - \text{CWS})$
 C: $W_{\text{input}} = kW_{i-1} + kW_{i-2} + kW_{i-3}$

where $C_p = 4.19 \text{ kJ/kg} \cdot ^\circ\text{C}$ & density of chilled water is assumed to be 1 kg/l

Percent heat balance = $[(A + C) - B] / B \times 100\%$

Note: In the event where hydraulic losses of pumps constitute substantial heat gain, $W_{\text{input}} / q_{\text{condenser}}$ may be adjusted to account for these additional heat gain. The value shall be determined from variable speed drive losses, motor efficiency and pump efficiency values certified by the manufacturer.


Worked Example 1-2(e)

Determining Heat Balance for Different Plant Configuration

Constant Primary & Variable Secondary Chilled Water System

Determining Heat Balance for Different Plant Configuration

Plant C – Constant Primary & Variable Secondary Chilled-Water System



A: $q_{\text{evaporator}} = \text{FM1} \times C_p \times (\text{CHWR} - \text{CHWS})$

B: $q_{\text{condenser}} = \text{FM2} \times C_p \times (\text{CWR} - \text{CWS})$

C: $W_{\text{input}} = kW_{i-1} + kW_{i-2} + kW_{i-3}$

where $C_p = 4.19 \text{ kJ/kg.}^\circ\text{C}$ & density of chilled water is assumed to be 1 kg/l

Percent heat balance = $[(A + C) - B] / B \times 100\%$

Note: In the event where hydraulic losses of pumps constitute a substantial heat gain, $W_{\text{input}}/ q_{\text{condenser}}$ may be adjusted to account for these additional heat gain. The value shall be determined from variable speed drive losses, motor efficiency and pump efficiency values certified by the manufacturer.

Worked Example 1-2(e)

Heat Balance Calculation


	(a) Chilled water supply temperature	(b) Chilled water return temperature	(c) Chilled water flow rate	(d) Condenser water supply temperature	(e) Condenser water return temperature	(f) Condenser water flow rate	(g) Chiller kW	(h) Heat Gain	(i) Heat Rejected	(j) Percent Heat Balance
dd/mm/yyyy hh:mm	°C	°C	L/s	°C	°C	L/s	kW	RT	RT	%
16/6/2012 15:00	6.70	12.60	84.10	29.4	35.5	97.65	308	591.14	709.65	-4.36
16/6/2012 15:01	6.71	12.50	84.20	29.5	35.4	97.60	309	580.81	686.03	-2.53
16/6/2012 15:02	6.72	12.30	84.30	29.6	35.3	97.55	310	560.41	662.44	-2.10
16/6/2012 15:03	6.73	12.10	84.20	29.7	35.2	97.50	311	538.68	638.86	-1.84
16/6/2012 15:04	6.74	12.20	84.10	29.8	35.1	97.55	312	547.05	615.95	3.22
16/6/2012 15:05	6.75	12.00	84.00	29.9	35	97.60	311	525.39	593.01	3.51
16/6/2012 15:06	6.74	12.30	84.10	29.8	35.1	97.65	310	557.07	616.58	4.64
16/6/2012 15:07	6.73	12.10	84.20	29.7	35.2	97.60	309	538.68	639.52	-2.03
16/6/2012 15:08	6.72	12.10	84.30	29.6	35.3	97.55	308	540.32	662.44	-5.21
16/6/2012 15:09	6.71	12.20	84.20	29.5	35.4	97.50	309	550.71	685.33	-6.82
16/6/2012 15:10	6.70	12.40	84.10	29.4	35.2	97.55	310	571.10	674.06	-2.20
16/6/2012 15:11	6.70	12.60	84.10	29.4	35.5	97.65	308	591.14	709.65	-4.36
16/6/2012 15:12	6.71	12.50	84.20	29.5	35.4	97.60	309	580.81	686.03	-2.53
16/6/2012 15:13	6.72	12.30	84.30	29.6	35.3	97.55	310	560.41	662.44	-2.10
16/6/2012 15:14	6.73	12.10	84.20	29.7	35.2	97.50	311	538.68	638.86	-1.84
16/6/2012 15:15	6.74	12.20	84.10	29.8	35.1	97.55	312	547.05	615.95	3.22
16/6/2012 15:16	6.75	12.00	84.00	29.9	35	97.60	311	525.39	593.01	3.51
16/6/2012 15:17	6.74	12.30	84.10	29.8	35.1	97.65	310	557.07	616.58	4.64
16/6/2012 15:18	6.73	12.10	84.20	29.7	35.2	97.60	309	538.68	639.52	-2.03
16/6/2012 15:19	6.72	12.10	84.30	29.6	35.3	97.55	308	540.32	662.44	-5.21
16/6/2012 15:20	6.71	12.20	84.20	29.5	35.4	97.50	309	550.71	685.33	-6.82
16/6/2012 15:21	6.70	12.40	84.10	29.4	35.2	97.55	310	571.10	674.06	-2.20
Total							6814	12,202.71	14,367.72	32.36
	Total data count									22
	Data Count > +5% error									0
	Data Count < -5% error									4
	Percentage of heat balance within ± 5%									82%

$$\text{Heat Gain (h)} = m \times C_p \times \Delta T = (c) \times 4.19 \text{kJ/kg} \cdot ^\circ\text{C} \times [(b) - (a)] / 3.517$$

$$\text{Heat Rejected (i)} = (f) \times 4.19 \text{ kJ/kg } ^\circ\text{C} \times [(e) - (d)] / 3.517$$

$$\text{Percent Heat Balance (j)} = [(g) / 3.517 + (h) - (i)] / (i) \times 100\%$$

System level heat balance plot (example)



Summary of Heat Balance (example)

	Quantity	Unit	Formula
Sum of total electrical energy used	6814	kWh	(A)
Sum of total cooling produced	12,202	RTh	(B)
Sum of total heat rejected	14,367	RTh	(C)
Chiller Plant Efficiency	0.56	kW/RT	(A) / (B)
Total Heat Balance Data Count	22	-	(D)
Data Count > 5% error	0	-	(E)
Data Count < 5% error	4	-	(F)
Data Count within ±5% error	18	-	(G) = (D) – (E) – (F)
% Heat Balance within ±5% error	82	%	(G) / (D) x 100%

Based on the above example, 82% of the heat balance calculation falls within ± 5% which fulfills the criterion of 80%.

Note : Actual heat balance shall be conducted over the entire normal operating hours with more than 80% of the computed heat balance within ±5% over one (1) week period.

Abbreviations used in Worked Example 1-2(e)

CH	Chiller	--
CHWP	Chilled Water Pump	-
CWP	Condenser Water Pump	-
CT	Cooling Tower	-
CHWS	Chilled Water Supply Temperature	°C
CHWR	Chilled Water Return Temperature	°C
CWS	Condenser Water Supply Temperature	°C
CWR	Condenser Water Return Temperature	°C
KW	Electrical Power Consumption	kW
$q_{\text{evaporator}}$	Cooling Load	kW or RT
$q_{\text{condenser}}$	Heat Rejection	kW or RT
W_{input}	Energy Input	kW
AHU	Air Handling Unit	
BP	Bypass Line	
BPV	Bypass Valve (2-Way Modulating)	
C_p	Specific Heat Capacity of Water	4.19 kJ/kg.°C

ENRB 1-3 NATURAL VENTILATION / MECHANICAL VENTILATION

Objectives	Encourage building that facilitates good natural ventilation or with provision for ventilation by efficient mechanical ventilation system.						
Applicability	<p>Applicable to non air-conditioned building spaces with aggregate areas > 10% of the total floor areas <u>excluding carparks, plant rooms and common areas.</u></p> <p><i>Important notes:</i> Where there is a combination of naturally ventilated and mechanical ventilated spaces, the points scored will only be based on the predominant ventilation modes of normally occupied spaces.</p>						
Baseline Standard	<p><u>1-3(a) Natural Ventilation</u></p> <ul style="list-style-type: none"> Natural ventilation with window openings facing North and South directions and building design that utilizes prevailing wind conditions to achieve adequate cross ventilation. <p><u>1-3(b) Mechanical Ventilation</u></p> <ul style="list-style-type: none"> Reference to fan system design criteria in CP 13: 1999 – Code of Practice for Mechanical Ventilation and Air-conditioning in buildings. <table border="1" style="margin-left: auto; margin-right: auto; border-collapse: collapse; text-align: center;"> <tr> <td colspan="2">Fan motor shall not exceed</td> </tr> <tr> <td>Constant volume</td> <td>Variable volume</td> </tr> <tr> <td>0.47 W/cmh</td> <td>0.74 W/cmh</td> </tr> </table>	Fan motor shall not exceed		Constant volume	Variable volume	0.47 W/cmh	0.74 W/cmh
Fan motor shall not exceed							
Constant volume	Variable volume						
0.47 W/cmh	0.74 W/cmh						
Requirements	<p><u>1-3(a) Natural Ventilation</u></p> <ul style="list-style-type: none"> Up to 32 points can be scored under natural ventilation. 20 points can be scored for the use of natural ventilation. Additional 1.6 points can be scored for every 10% of NV areas with window openings facing north and south directions and cross ventilation. <p style="text-align: center;">Points scored = 1.6 x (% of NV areas / 10)</p> <p>Note: In Singapore, the prevailing wind comes from two predominant directions; that is the north to North-East during the Northeast monsoon season and South to South-East during the South-West monsoon season. Hence, buildings with window openings facing the North and South directions have the advantage of the prevailing wind conditions which would enhance indoor thermal comfort.</p> <p>It is not necessary for the window openings to be located perpendicularly to the prevailing wind direction. An oblique angle is considered acceptable (see illustrations below).</p>						




Illustration - Building layout shows all rooms with window openings facing the north and south directions.

1-3(b) Mechanical Ventilation

- Up to 32 points can be scored for the use of energy efficient MV system.
- 0.6 points can be scored for every subsequent 1% improvement from baseline.

Documentary Evidences

For 1-3(a) Natural Ventilation

- Architectural plan layouts showing the rooms with highlights of those with window openings in the N-S direction and/or with air-conditioned systems;
- Calculation showing the percentage of rooms with window openings facing north and south directions in the prescribed tabulated format as shown in the worked example 1-3(a)(i).

For 1-3(b) Mechanical Ventilation

- Architectural plan layouts showing the mode of ventilation for areas / rooms that are mechanically ventilated
- MV fan equipment schedule and technical specifications.

References

CP 13: 1999 – Code of Practice for Mechanical Ventilation and Air-conditioning in Buildings.

Worked Example 1-3(a)(i)

Background information for Natural Ventilation example

An institutional building comprises two 3-storey classroom block A and B with majority of the window openings facing the N-S direction and cross ventilation, a 4 storey classroom Block C with window opening in the E-W direction and three blocks of office, meeting rooms and computer rooms which are air-conditioned.

Ref	Description	Rooms with window openings in the N-S direction (a)	Total no. of naturally ventilated rooms (b)	% of rooms with window openings in N-S direction

1	Classroom Blk A & B	40	60	$\Sigma (a) / \Sigma (b) \times 100\%$
2	Classroom Blk C	0	40	
3	Offices, meeting rooms and computer rooms with air-conditioning	NA	NA	
Total :		40	100	

Points scored for window openings = $1.6 \times (\% \text{ of units} / 10\%)$

facing N-S directions = $1.6 \times [(\Sigma (a) / \Sigma (b) \times 100\%) / 10\%]$
= $1.6 \times [(40/100 \times 100\%) / 10]$
= 6.4 points

Total points scored for Natural Ventilation = $20 + 6.4$
= 26.4 points < 32 points (max)

Worked Example 1-3(a)(i)

Background information for Mechanical Ventilation example

A small industrial factory development comprises of 4-storey block with 6 workshop spaces that are mechanically ventilated.

MV fan schedule:

Workshop	Fan	Fan Type	Air Flow Rate (CMH)	Fan Input Power (kW)	Fan Efficiency (W/CMH)
1	FAF 1-1	Axial	39000	8.28	0.21
2	FAF 1-2		39000	8.28	0.21
3	FAF 1-3		39000	8.28	0.21
4	FAF 2-1		24000	3.92	0.16
5	FAF 2-2		24000	3.92	0.16
6	FAF 2-3		24000	3.92	0.16
1	EAF 1-1		39000	8.28	0.21
2	EAF 1-2		39000	8.28	0.21
3	EAF 1-3		39000	8.28	0.21
4	EAF 2-1		24000	3.92	0.16
5	EAF 2-2		24000	3.92	0.16
6	EAF 2-3		24000	3.92	0.16
TOTAL			378,000	73.24	

Total fan input power = **73.24 kW**

Total air flow rate = **378,000 CMH**

Baseline: Total fan power = 378,000 CMH x 0.47 W/CMH
= 177.66 kW

Points scored = 0.6 x (% improvement)
= 0.6 x [(177.66 – 73.24)/177.66 x 100]
= 0.6 x 58.8
= 35 points > 32 (max)

Therefore, point scored should be 32 points.

ENRB 1-4 ARTIFICIAL LIGHTING

Objectives	Encourage the use of better efficient lighting to minimize energy consumption from lighting usage while maintaining proper lighting level.
Applicability	Applicable to lighting provisions for the type of usage specified in the CP 24:1999 Clause 7 – Lighting power budget.
Baseline Standard	Maximum lighting power budget stated in Annex 1 of the GM ENRB Version 3.
Requirements	<ul style="list-style-type: none"> • Up to 13 points if includes tenants' lighting provision OR up to 5 points if tenants' lighting provision is excluded for the improvement in the lighting power consumption. • 0.3 point for every percentage improvement in the lighting provisions over the baseline standard. That is Points scored = 0.3 x (% improvement) • Display and specialized lightings are to be included in the calculation of lighting power budget. For hotels and offices, task lightings are to be included in the lighting power budget computation.
Documentary Evidences	<ul style="list-style-type: none"> • Lighting layout plan; • Calculation of the lighting power budget showing individual locations with area in m², fittings type, power consumption in watt, ballast loss, no. of lamps, total power consumption in watt, power density watt/m², reference power density watt/m², reference total power consumption and the percentage improvement in the prescribed tabulated format as shown in the worked example 1-4; • Technical product information of the lighting luminaries used.
References	<ul style="list-style-type: none"> • CP 24: 1999 – Code of Practice for Energy Efficiency Standard for Building Services and Equipment. • SS 531: Part 1: 2006 – Code of Practice for Lighting of Work Places – Indoor • Annex 1 of Green Mark for Existing Non-Residential Buildings (Version 3.0) : Maximum lighting power budget (including ballast loss)
Worked Example 1-4	<ul style="list-style-type: none"> ▪ Determine the total power consumption based on the lighting layout design for each area and light fitting types used. ▪ Calculate the total power consumption based on the maximum lighting power budget stated in the References. ▪ Calculate the percentage improvement in the total power consumption.

**Worked Example
1-4 – Cont'd**

Table 1-4-1: Total power consumption based on each fitting type

Description	Areas (m ²) (A)	Light Fitting Type (B)	Power Consumption per fitting (W) (C)	Ballast Loss (W) (D)	No. of Fittings (E)	Total power consumption based on fitting type [(C+D) x (E)]
Office Type 1	1500	T5	28	3	490	15190
Office Type 2	1250	T5	28	3	420	13020
Meeting Room	75	T8	36	6	15	630
		Surface downlight	26	3	16	464
Corridors Type 1	150	T5	28	3	40	1240
Corridors Type 2	205	T5	28	3	40	1240
		Surface downlight	70	3	10	730
Atrium	850	T8	28	6	174	5916
		Surface downlight	150	3	10	1530
Carparks	7500	T5	28	3	870	26970
Staircase	300	T5	28	3	40	1240
Male toilets	45	PLC	13	3	15	240
Female toilets	45	PLC	13	3	15	240
Total						68650

Table 1-4-2 : Total power consumption based on design and SS 530 requirements

Description	Areas (m ²) (A)	Design Data		SS 530 Requirements	
		Total Power Consumption (by area)(W) (F)	Design Lighting Power Budget (W/m ²) (F/A)	Reference Lighting Power Budget (W/m ²) (H)	Reference Total Power Consumption (by area) (W) (H x A)
Office Type 1	1500	15190	10.13	15	22,500
Office Type 2	1250	13020	10.42	15	18,750
Meeting Room	75	1094	14.59	15	1,125
Corridors Type 1	150	1240	8.27	10	1,500
Corridors Type 2	205	1970	9.61	10	2,050
Atrium	850	7446	8.76	10	8,500
Carparks	7500	26970	3.60	5	37,500
Staircase	300	1240	4.13	6	1,800
Male toilets	45	240	5.33	5.33	240
Female toilets	45	240	5.33	5.33	240
Total		68650			94,205

$$\begin{aligned}\% \text{ improvement in the lighting power consumption} &= [\Sigma (HxA) - \Sigma (F)] / \Sigma (HxA) \times 100\% \\ &= (94205-68650)/94205 \times 100\% \\ &= 27.13\%\end{aligned}$$

$$\text{Points scored} = 0.3 \times 27.13 = 8.14 \text{ points}$$

Therefore, points scored should be 8.1 points if tenant's lighting is included ;
and points scored should be 5 points (max) if tenant's lighting is excluded.

ENRB 1-5 VENTILATION IN CARPARKS

Objectives	Encourage the use of energy efficient design and control of ventilation systems in carpark.
Applicability	Applicable to all carpark spaces in the development.
Baseline Standard	Nil
Requirements	<p><u>1-5(a)</u></p> <ul style="list-style-type: none"> 4 points can be scored if the carpark spaces are fully naturally ventilated. <p><u>1-5(b)</u></p> <ul style="list-style-type: none"> Up to 4 points can be scored for carpark spaces that are mechanically ventilated. Points can only be scored for the use of carbon monoxide (CO) sensors in regulating the demand for the mechanical ventilation (MV) used; 2.5 points for carpark spaces using fume extract system and 2 points for those with MV with or without supply. <p>Note: Where there is a combination of different ventilation mode adopted for carpark design, the points scored under this requirement will be prorated accordingly.</p>
Documentary Evidences	<p><u>For 1-5(a) and (b)</u></p> <ul style="list-style-type: none"> Plan layouts showing all carpark provisions with highlights of the carpark spaces that are designed to be naturally ventilated and/or mechanical ventilated; Plan layouts indicating the locations of CO sensors and the mode of ventilation adopted for the design; and Calculation showing the points allocation if there is a combination of different ventilation modes adopted for the carpark design.
References	CP 13:1999 – Code of Practice for Air-Conditioning and Mechanical Ventilation in Buildings.
Worked Example 1-5	<p>A building has a 6-storey naturally ventilated carpark and one level of mechanically ventilated basement carpark with CO sensors installed to regulate MV.</p> <p>Areas of naturally ventilated carpark = $6 \times 600 = 3600 \text{ m}^2$</p> <p>Areas of basement carpark = 600 m^2</p> <p>Total areas = 4200 m^2</p> <p>Points scored for ENRB 1-5 = $(3600/4200) \times 4 + (600/4200) \times 2$</p> <p>= 3.71 points < 4 points (max)</p>

ENRB 1-6 VENTILATION IN COMMON AREAS

Objectives	Encourage the use of energy efficient ventilation systems in common areas.
Applicability	Applicable to the following common areas:- <ul style="list-style-type: none"> ▪ Toilets ▪ Staircases ▪ Corridors ▪ Lift Lobbies ▪ Atriums
Baseline Standard	Nil
Requirements	<ul style="list-style-type: none"> • Up to 5 points can be scored for the use of natural ventilation as an effective passive cooling design strategy to reduce the energy used by air-conditioning systems in these common areas. • Extent of coverage: At least 90% of each applicable area (by numbers). • Points are scored based on the mode of ventilation provided in these applicable areas. • Natural ventilation – 1.5 points for each common area • Mechanical ventilation – 0.5 point for each common area
Documentary Evidences	<ul style="list-style-type: none"> • Plan layouts showing the applicable areas and the respective modes of ventilation; and • Schedules showing the numbers, locations of the applicable areas and the modes of ventilation used.
References	CP 13:1999 – Code of Practice for Air-Conditioning and Mechanical Ventilation in Buildings.
Worked Example 1-6	<p>An existing building has the following details :</p> <ul style="list-style-type: none"> • No. of toilets = 45 ; where 10 units are mechanical ventilated and 35 units are natural ventilated. <p style="padding-left: 40px;">% of toilet units with natural ventilation = $(35)/45 = 77.8\% < 90\%$ and hence only 0.5 points shall be awarded for this item</p> <ul style="list-style-type: none"> • No. of staircases = 100 ; all are mechanical ventilated. Points scored is 0.5 point • No. of lift lobbies = 22 ; all are naturally ventilated. Points scored is 1.5 points <p>Total points scored for ENRB 1-6 = $0.5 + 0.5 + 1.5 = 2.5$ points < 5 points(max)</p>

ENRB 1-7 LIFTS AND ESCALATORS

Objectives	Encourage the use of energy efficient lifts and escalators.
Applicability	Applicable to <u>all</u> lifts and escalators in the building.
Baseline Standard	Nil.
Requirements	<ul style="list-style-type: none"> • 1 point can be scored for the use of lifts with energy efficient features such as AC variable voltage and variable frequency (VVVF) motor drive or equivalent, and sleep mode features. • 1 point can be scored for the use of escalators with motion sensors to regulate usage.
Documentary Evidences	<ul style="list-style-type: none"> • Technical specification indicating the types of lifts, escalators and related features used; and
References	-
Worked Example 1-7	<p>An existing building has the following provision :</p> <p>Two lift types : (a) Type L1 with VVVF motor drive and sleep mode features (ii) Type L2 with VVVF motor drive and sleep mode features</p> <p>Two escalator types : (a) Type E1 with VVVF motor drive and motion sensors (ii) Type E2 without VVVF motor drive and motion sensors</p> <p>1 points for the use of lifts with VVVF and sleep mode features.</p> <p>No point for escalators as not all escalators are designed with motion sensors.</p> <p>Points scored for ENRB 1-7 = 1 point</p>

ENRB 1-8 ENERGY EFFICIENT PRACTICES & FEATURES

<p>Objectives</p>	<p>Encourage the use of energy efficient practices and features which are innovative and have positive environmental impact in terms of energy saving.</p>
<p>Applicability</p>	<p>Applicable to practices and features that are not listed in the requirements under Part 1 – Energy Efficiency.</p>
<p>Baseline Standard</p>	<p>-</p>
<p>Requirements</p>	<p><u>1-8 (a)</u></p> <ul style="list-style-type: none"> • 1 point can be scored for the computation of using Energy Efficiency Index (EEI) as a building performance indicator to measure the building’s unit area energy consumption for monitoring and improvements. <p><u>Calculation of EEI :</u></p> <p>EEI = [(TBEC – DCEC) / (GFA – DCA)] x (NF/OH)</p> <p><i>where:</i></p> <ul style="list-style-type: none"> (a) TBEC : Total building energy consumption (kWh/year) (b) DCEC : Data centre energy consumption (kWh/year) © GFA : Gross floor area (exclude car park area) (m²) (d) DCA : Data centre area (m²) (e) NF : Normalising factor based on a typical weekly operating hours that is <u>55 hrs/week</u> (g) OH : Weighted weekly operating hours (hrs/week) <p>Note :</p> <ul style="list-style-type: none"> (1) EEI is based on 100% occupancy rate for consistency. (2) All major energy consumption equipments are to be included in the estimation of total building energy consumption. (3) For industrial buildings, process load should be excluded. <p><u>1-8(b)</u></p> <ul style="list-style-type: none"> • Up to 2 points can be scored for the use of energy efficiency products that are certified by approved local certification body. 0.5 point for each energy efficient type. <p><u>1-8(c)</u></p> <ul style="list-style-type: none"> • Up to 9 points can be scored for the use of the following approved energy efficient features depending on the potential energy saving. 2 points for every 1% energy saving over total building energy consumption. <ul style="list-style-type: none"> ▪ Re-generative lift ▪ Light shelves ▪ Photo sensors ▪ Motion sensors ▪ Heat recovery devices ▪ Sun pipes for natural lighting ▪ Heat pumps <p><i>Important notes:</i> For features that are not listed ENRB 1-8© above, it is required to submit the details showing the positive environmental impacts and potential energy savings of the proposed features to BCA for assessment before submittal of Green Mark Score.</p>

Documentary Evidences	<p><u>For 1-8(a)</u></p> <ul style="list-style-type: none"> • Calculation of the Energy Efficiency Index (EEI) in the prescribed tabulated format as shown in the worked example 1-8(a). • Twelve(12) months energy bills <p><u>For 1-8(b)</u></p> <ul style="list-style-type: none"> • Certification from approved local certification body (such as SGLS and SGBC) which spelt out the material certification standards, rating and details. • Technical product information. <p><u>For 1-8(c)</u></p> <ul style="list-style-type: none"> • Write-up and drawings showing the provision of the proposed energy efficient features and the extent of implementation where applicable; • Technical product information on the energy efficient features used; and • Calculation of the potential energy savings that could be reaped from the use of these features. 																												
References	<ul style="list-style-type: none"> • Singapore Green Building Council (SGBC) Certified products : http://www.sgbc.sg/index.php/certification/assess/C109/ • Singapore Environmental Council at http://www.greenlabel.sg/sgls 																												
Worked Example 1-8(a)	<p><u>For 1-8(a)</u></p> <ul style="list-style-type: none"> • Tabulate the total annual building electricity consumption (TBEC) based on 12 months energy bills. • Compute the Energy Efficiency Index of the building . <p><u>Background info :</u></p> <p>Assume an existing building with GFA of 21,835 m², operating hours per week is 60 hours at 100% occupancy rate. No data centre in the building.</p> <table border="1" data-bbox="375 1294 1098 1899"> <thead> <tr> <th>Month</th> <th>Total Electricity Bill</th> </tr> </thead> <tbody> <tr><td>Mar-11</td><td>756,730</td></tr> <tr><td>Apr-11</td><td>819,278</td></tr> <tr><td>May-11</td><td>819,538</td></tr> <tr><td>Jun-11</td><td>742,540</td></tr> <tr><td>Jul-11</td><td>806,854</td></tr> <tr><td>Aug-11</td><td>847,571</td></tr> <tr><td>Sep-11</td><td>865,244</td></tr> <tr><td>Oct-11</td><td>834,212</td></tr> <tr><td>Nov-11</td><td>872,959</td></tr> <tr><td>Dec-11</td><td>847,652</td></tr> <tr><td>Jan-12</td><td>935,965</td></tr> <tr><td>Feb-12</td><td>767,112</td></tr> <tr> <td>TOTAL (kWH/yr)</td> <td>9,915,655</td> </tr> </tbody> </table> <p style="text-align: center;"> $EEI = [(TBEC - DCEC) / (GFA - DCA)] \times (NF / OH)$ $= [(9,915,655 - 0) / (21,836 - 0)] \times (55 / 60)$ </p>	Month	Total Electricity Bill	Mar-11	756,730	Apr-11	819,278	May-11	819,538	Jun-11	742,540	Jul-11	806,854	Aug-11	847,571	Sep-11	865,244	Oct-11	834,212	Nov-11	872,959	Dec-11	847,652	Jan-12	935,965	Feb-12	767,112	TOTAL (kWH/yr)	9,915,655
Month	Total Electricity Bill																												
Mar-11	756,730																												
Apr-11	819,278																												
May-11	819,538																												
Jun-11	742,540																												
Jul-11	806,854																												
Aug-11	847,571																												
Sep-11	865,244																												
Oct-11	834,212																												
Nov-11	872,959																												
Dec-11	847,652																												
Jan-12	935,965																												
Feb-12	767,112																												
TOTAL (kWH/yr)	9,915,655																												

	$= (9,915,655 / 21,836) \times 0.917$ $= 454.12 \times 0.917 = 416.41 \text{ kWh/m}^2/\text{yr}$ <p>Points scored for ENRB 1-8(a) = 1 point</p>
<p>Worked Example 1-8©</p>	<p>An existing building uses motion sensors to control the lightings in all staircases and toilets.</p> <p>(i) <u>Toilets</u></p> <p>Total light fittings to be controlled by motion sensors = 2 x 350 nos.</p> <p>Power consumption by light fitting = 2 x 350 x 42 W = 29,400 W</p> <p>Assume 5 hours per day that the light fittings are off when it is not occupied.</p> <p>Electricity saving = 29,400 W x 5 hours = 147 kWh/day</p> <p>Annual electricity saving = 147 x 365 = 53,655 kWh/yr</p> <p>(ii) <u>Staircases</u></p> <p>Total light fittings to be controlled by motion sensors = 2 x 180 nos.</p> <p>Power consumption by light fitting = 2 x 180 x 21 W = 7,560 W</p> <p>Assume 10 hours per day that the light fittings are off when it is not used</p> <p>Electricity saving = 7,560 W x 10 hours = 75.6 kWh/day</p> <p>Annual electricity saving = 75.6 x 365 = 27,594 kWh/yr</p> <p>Total annual electricity saving using motion sensors = 53,655 + 27,594 = 81,249 kWh/yr</p> <p>% energy savings = Energy savings / Total building energy consumption</p> <p>% energy savings = 81,249 / 9,915,655 = 0.819 %</p> <p>Points scored for 1-8© = 2 points for every 1 % energy saving = 2 x 0.819 = 1.64 points</p>

Objectives	To establish energy policy and targets for the better building energy efficiency
Applicability	Generally applicable to all buildings.
Baseline Standard	Nil.
Requirements	<p>(a) 0.5 point can be scored for establishing Energy Policy, energy targets and regular review with top management.</p> <p>(b) 0.5 point can be scored for having measures or strategies for energy improvement plans to achieve the energy target set over the next 3 years. Committed energy savings accrued from the proposed measures should be quantified.</p>
Documentary Evidences	<p>(a) Energy Policy with senior management’s endorsement and energy targets for next 3 years.</p> <p>(b) List of energy efficiency improvement plans for the next 3 years and the computation of energy savings for each measure to arrive at the energy targets.</p>
References	<p>An energy policy is a written document stating the way the building management will use energy and what targets it hopes to achieve. It should show how the building management intends to achieve the targets and plans for how energy efficiency will continually be improved in the future.</p> <p>The policy should be developed in consultation with the senior management so as to secure commitment from the management.</p>
Worked Example 1-9	<p><u>Sample of Energy Policy</u></p> <p><u>Goals:</u></p> <p>ABC Pte Ltd is committed to the responsible management of energy and water and by using these resources in the most efficient and environmentally responsible manner possible. Towards this end, ABC Pte Ltd shall:</p> <p>(a) improve energy efficiency continuously by implementing effective energy management</p> <p>(b) minimize environmental impact</p> <p>(c) have programs that support all operations and customer satisfaction while providing a safe and comfortable work environment.</p>

- (d) maintain an acceptable level of comfort level for staff, tenants and other building users.

Strategy:

- (a) Benchmark energy use of all facilities by January 2012.
- (b) Compared with 2011 baseline, reduce energy consumption by 3 percent per square metres by 2012 and 5 percent per square metres by 2014.
- (c) Each year realistic energy reduction targets will be set and monitored regularly.
- (d) To regularly monitor and assess the energy, gas and water consumption.
- (e) Any unusually high usage will be investigated and corrected.
- (f) Educate employees about how to save energy at work and at home.
- (g) Our target for energy and water performance are:

	Current yearly performance	Target yearly performance	% target reduction per year
Electricity kWh/m ² /yr	9,915,000	9,615,000	3%

Applicability:

This policy shall apply to all facilities, business units and employees.

Approved by:

[Company CEO]

ENRB 1-10 RENEWABLE ENERGY

Objectives	Encourage the use of renewable energy sources in buildings.											
Applicability	Includes all renewable energy sources (e.g. solar panels, wind turbine)											
Baseline Standard	Nil.											
Requirements	<p>Up to 15 points can be scored based on the building energy efficiency index and percentage replacement of electricity by the renewable energy source :</p> <table border="1"> <thead> <tr> <th rowspan="2">Expected Energy Efficiency Index (EEI)</th> <th colspan="2">Every 1 % replacement of electricity (based on total electricity consumption) by renewable energy source (Up to 15 points)</th> </tr> <tr> <th>Include tenants' usage</th> <th>Exclude tenants' usage</th> </tr> </thead> <tbody> <tr> <td>≥ 50 kWh/m²/yr</td> <td>5 points</td> <td>3 points</td> </tr> <tr> <td>< 50 kWh/m²/yr</td> <td>3 points</td> <td>1.5 points</td> </tr> </tbody> </table> <p>Note : For computation of EEI, refer to worked example 1-8(a) under ENRB 1-8 – Energy Efficient Features</p>	Expected Energy Efficiency Index (EEI)	Every 1 % replacement of electricity (based on total electricity consumption) by renewable energy source (Up to 15 points)		Include tenants' usage	Exclude tenants' usage	≥ 50 kWh/m ² /yr	5 points	3 points	< 50 kWh/m ² /yr	3 points	1.5 points
Expected Energy Efficiency Index (EEI)	Every 1 % replacement of electricity (based on total electricity consumption) by renewable energy source (Up to 15 points)											
	Include tenants' usage	Exclude tenants' usage										
≥ 50 kWh/m ² /yr	5 points	3 points										
< 50 kWh/m ² /yr	3 points	1.5 points										
Documentary Evidences	<ul style="list-style-type: none"> • Description and drawings on the renewable energy system and the extent of implementation; • Technical product information on the salient features of the renewable energy system and the expected renewable energy generated; and • Calculation of the percentage replacement of electricity compared with the total annual electricity consumption of the building. 											
References	Nil.											

(I) Other Green Requirements

Part 2 – Water Efficiency

- ENRB 2-1 Water Monitoring
- ENRB 2-2 Water Efficient Fittings
- ENRB 2-3 Alternative Water Sources
- ENRB 2-4 Water Efficiency Improvement Plans
- ENRB 2-5 Irrigation System and Landscaping
- ENRB 2-6 Cooling Towers

ENRB 2-1 WATER MONITORING

Objectives	Promote the use of private meters and leak detection system for better control and monitoring of water usage.
Applicability	Applicable to sub-metering provisions for major water uses of the building developments.
Baseline Standard	Nil.
Requirements	<p><u>2-1 (a)</u></p> <ul style="list-style-type: none"> • 1 point can be scored if the building’s water consumption is monitored on monthly basis. <p><u>2-1 (b)</u></p> <ul style="list-style-type: none"> • 1 point can be scored if private water meters are provided for major water uses e.g. cooling tower, water features, irrigation system, swimming pools, tenants’ usage where applicable. <p><u>2-1 (c)</u></p> <ul style="list-style-type: none"> • 1 point can be scored if there is provision of automated and/or smart metering for the monitoring and leak detection.
Documentary Evidences	<p><u>2-1 (a)</u></p> <ul style="list-style-type: none"> • Tabulation of the monthly water usage for the last 12 months and a graph showing the consumption trend from PUB monthly bills and each private meter’s recording. <p><u>2-1 (b)</u></p> <ul style="list-style-type: none"> • Documentary evidences and/or photographs of each private water sub-meters and records of recording and monitoring; or • Schematic drawings of cold water distribution system showing the location of the sub-meters provided. <p><u>2-1 (c)</u></p> <ul style="list-style-type: none"> • Documentary evidences and trend logging records to show the provision of the automated metering and leak detection system.
References	Nil.

ENRB 2-2 WATER EFFICIENT FITTINGS

Objectives	Reduce the use of potable water by encouraging the use of water efficient fittings under the PUB Water Efficiency Labeling Scheme (WELS) or adopt equivalent water efficient flowrate/flush volumes for the water fittings.									
Applicability	<p>Applicable to all water fittings covered by the WELS as follows:</p> <ul style="list-style-type: none"> ▪ Basin taps and mixers ▪ Shower taps and mixers or showerheads ▪ Sink/bib taps and mixers ▪ Urinals and Urinal Flush Valves ▪ Dual-Flush Low Capacity Flushing Cisterns <p>Note: Water closets in <u>public toilets</u> fitted with flush valve and automatic flush devices can be excluded in computation.</p>									
Baseline Standard	As specified under PUB Water Efficiency Labelling Scheme (WELS).									
Requirements	<ul style="list-style-type: none"> • Up to 12 points can be scored based on the number and water efficiency rating of the fitting type used. <table border="1" data-bbox="435 965 1417 1104"> <thead> <tr> <th style="background-color: #e0f2f1;">WELS Rating</th> <th style="background-color: #e0f2f1;">Water Efficiency</th> <th style="background-color: #e0f2f1;">Weightage for Point Allocation</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">✓✓</td> <td style="text-align: center;">Very Good</td> <td style="text-align: center;">9</td> </tr> <tr> <td style="text-align: center;">✓✓✓</td> <td style="text-align: center;">Excellent</td> <td style="text-align: center;">12</td> </tr> </tbody> </table> <p>Or</p> <ul style="list-style-type: none"> • 9 points can be scored if the building is certified with PUB Water Efficient Building. 	WELS Rating	Water Efficiency	Weightage for Point Allocation	✓✓	Very Good	9	✓✓✓	Excellent	12
WELS Rating	Water Efficiency	Weightage for Point Allocation								
✓✓	Very Good	9								
✓✓✓	Excellent	12								
Documentary Evidences	<ul style="list-style-type: none"> • Water fitting schedules showing the numbers, types and the approved rating of the water fittings in the prescribed tabulated format shown in the worked example. • Documentary evidences such as WELS water efficiency label, catalogues, etc. • A copy of PUB Water Efficient Building certificate. 									
References	PUB WELS - http://www.pub.gov.sg/wels/rating/Pages/Requirements.aspx									

Worked Example 2-2

Example of a water fitting schedule showing the numbers, types and the approved rating of the proposed fittings.

Table 2-2 –Computation of the percentage of water fittings under WELS

Ref	Water Fitting Type	WELS rating		Mandatory Requirement MWELS	Total no. based on fitting type
		Excellent	Very Good	Good	
1	Shower taps and mixers	0	30	30	60
2	Basin taps and mixers	200	0	10	210
3	Sink/bib taps and mixers	0	0	0	0
4	Dual-flush low capacity flushing cisterns	0	80	0	80
5	Urinals and urinal flush valves	50	0	0	50
Total no. based on rating (A)		250	110	40	$\sum A = 400$
Weightage (B)		12	9	0	-
Total (AxB)		3000	990	0	$\sum(AxB) = 3990$

$$\begin{aligned} \text{Points scored} &= \sum(AxB) / \sum A \\ &= 3990 / 400 \\ &= 9.98 \end{aligned}$$

Points scored for ENRB 2-2(a) = 9.98 points

ENRB 2-3 ALTERNATIVE WATER SOURCES

Objectives	Use of suitable systems that utilize alternative water sources for non-potable uses such as irrigation, washing, water features, toilet flushing, etc (excluding cooling tower make-up water) to reduce use of potable water. Alternative sources can be referred to rainwater, greywater, NEWater, AHU condensate and recycled water from approved sources.																																																								
Applicability	Applicable to all buildings.																																																								
Baseline Standard	Nil.																																																								
Requirements	<p>Up to 3 points can be scored based on percentage reduction in potable water usage of the applicable uses.</p> <table border="1" data-bbox="453 779 1174 965"> <thead> <tr> <th>Percentage reduction</th> <th>Points</th> </tr> </thead> <tbody> <tr> <td>> 50 %</td> <td>3 points</td> </tr> <tr> <td>< 10 % to 50 %</td> <td>2 points</td> </tr> <tr> <td>< 10 %</td> <td>1 point</td> </tr> </tbody> </table>	Percentage reduction	Points	> 50 %	3 points	< 10 % to 50 %	2 points	< 10 %	1 point																																																
Percentage reduction	Points																																																								
> 50 %	3 points																																																								
< 10 % to 50 %	2 points																																																								
< 10 %	1 point																																																								
Documentary Evidences	<ul style="list-style-type: none"> • Relevant schematics showing the location and design of the non-potable water source. • Calculation showing the percentage reduction of potable water using the alternative water sources. • PUB water bills showing monthly water consumption. 																																																								
References	Nil.																																																								
Worked Example	<p>Assuming rainwater is used for irrigation and the consumptions from PUB bills are as shown:-</p> <table border="1" data-bbox="432 1458 1415 2011"> <thead> <tr> <th>Months</th> <th>PUB Water (m³)</th> <th>NEWater (m³)</th> <th>Total (m3)</th> </tr> </thead> <tbody> <tr> <td>January</td> <td>1,774</td> <td>149</td> <td>1,923</td> </tr> <tr> <td>February</td> <td>2,018</td> <td>106</td> <td>2,124</td> </tr> <tr> <td>March</td> <td>2,744</td> <td>183</td> <td>2,927</td> </tr> <tr> <td>April</td> <td>2,227</td> <td>185</td> <td>2,412</td> </tr> <tr> <td>May</td> <td>2,575</td> <td>101</td> <td>2,676</td> </tr> <tr> <td>June</td> <td>2,650</td> <td>168</td> <td>2,818</td> </tr> <tr> <td>July</td> <td>2,324</td> <td>195</td> <td>2,519</td> </tr> <tr> <td>August</td> <td>2,567</td> <td>181</td> <td>2,748</td> </tr> <tr> <td>September</td> <td>2,657</td> <td>146</td> <td>2,803</td> </tr> <tr> <td>October</td> <td>2,612</td> <td>113</td> <td>2,725</td> </tr> <tr> <td>November</td> <td>938</td> <td>122</td> <td>1,060</td> </tr> <tr> <td>December</td> <td>1,986</td> <td>177</td> <td>2,163</td> </tr> <tr> <td>Total (m3/yr)</td> <td>27,072</td> <td>1,826</td> <td>28,898</td> </tr> </tbody> </table>	Months	PUB Water (m ³)	NEWater (m ³)	Total (m3)	January	1,774	149	1,923	February	2,018	106	2,124	March	2,744	183	2,927	April	2,227	185	2,412	May	2,575	101	2,676	June	2,650	168	2,818	July	2,324	195	2,519	August	2,567	181	2,748	September	2,657	146	2,803	October	2,612	113	2,725	November	938	122	1,060	December	1,986	177	2,163	Total (m3/yr)	27,072	1,826	28,898
Months	PUB Water (m ³)	NEWater (m ³)	Total (m3)																																																						
January	1,774	149	1,923																																																						
February	2,018	106	2,124																																																						
March	2,744	183	2,927																																																						
April	2,227	185	2,412																																																						
May	2,575	101	2,676																																																						
June	2,650	168	2,818																																																						
July	2,324	195	2,519																																																						
August	2,567	181	2,748																																																						
September	2,657	146	2,803																																																						
October	2,612	113	2,725																																																						
November	938	122	1,060																																																						
December	1,986	177	2,163																																																						
Total (m3/yr)	27,072	1,826	28,898																																																						

	<p>Rainwater consumption = 1,826 m³/yr Total water consumption = 28,898 m³/yr Percentage reduction in potable water = 1,826 / 28,898 = 6.32%</p> <p>Points scored for ENRB 2-3 = 1 point</p>
--	--

ENRB 2-4 WATER EFFICIENCY IMPROVEMENT PLANS

Objectives	Establish plans and strategies to reduce the dependency of potable water usage.
Applicability	Applicable to all buildings.
Baseline Standard	Nil
Requirements	<ul style="list-style-type: none"> • 1 point can be scored if there are intent, measures and implementation strategies for water efficiency improvement plans over the next 3 years. • Committed water savings accrued from the proposed measures should be quantified.
Documentary Evidences	<ul style="list-style-type: none"> • Water improvement plan and proposed measures to achieve these targets for the next three years. • Calculation showing the estimated water savings for each proposed measure.
References	Nil.

ENRB 2-5 IRRIGATION SYSTEM AND LANDSCAPING

Objectives	Provision of suitable control systems for irrigation system and use of plants that require minimal irrigation to reduce potable water consumption.
Applicability	Applicable to buildings with landscaping provision.
Baseline Standard	-
Requirements	<p><u>2-5(a)</u> 1 point can be scored if more than 50% of the landscape areas are served by water efficient irrigation system with features such as rain sensor, soil moisture sensor or equivalent control system.</p> <p><u>2-5(b)</u> 1 point can be scored if at least 50% of the landscape areas consist of drought tolerant plants that require minimal irrigation.</p>
Documentary Evidences	<p><u>2-5(a)</u></p> <ul style="list-style-type: none"> • Write up and details for the water efficient irrigation system; • Relevant layout plans showing the overall landscape areas and the areas that are using the system; and • Calculation to determine the percentage of the landscape areas that are using the system. <p><u>2-5(b)</u></p> <ul style="list-style-type: none"> • Relevant layout plans showing the overall landscape areas and the areas that use drought tolerant plants or plants that require minimal irrigation; and • Calculation showing the percentage of the landscape areas that use drought tolerant plants or plants that require minimal irrigation.
References	The list of drought tolerant / resistant plant species may be obtained from the online website: http://florafauweb.nparks.gov.sg/ ; go to "Browse Plants" > "Plant Characteristics & Use" > "Green Roof".

ENRB 2-6 COOLING TOWERS

Objectives	Reduce potable water consumption for cooling purpose.
Applicability	Applicable to building developments with water-cooled central chillers systems, and water-cooled package units.
Baseline Standard	Nil.
Requirements	<p><u>2-6 (a)</u> 1 point can be scored for the use of cooling tower water treatment system which can achieve 7 or better cycles of concentration at acceptable water quality.</p> <p><u>2-6(b)</u> 1 point can be scored for the use of NEWater or on-site recycled water from approved sources to meet the water demand for cooling tower purpose.</p>
Documentary Evidences	<p><u>2-6(a)</u> Lab test showing cooling tower water treatment system can achieve 7 or better cycles of concentration at acceptable water quality.</p> <p><u>2-6(b)</u> Relevant drawings and details showing how the NEWater or other recycled water source is used for the cooling tower water demand.</p>
References	Nil.

(II) Other Green Requirements

Part 3 – Sustainable Operation & Management

- ENRB 3-1 Building Operation & Maintenance
- ENRB 3-2 Post Occupancy Evaluation
- ENRB 3-3 Waste Management
- ENRB 3-4 Sustainable Products
- ENRB 3-5 Greenery
- ENRB 3-6 Environmental Protection
- ENRB 3-7 Green Transport

ENRB 3-1 BUILDING OPERATION & MAINTENANCE

Objectives	To encourage the adoption of green practices that is environmentally friendly and sustainable in the operation and maintenance of a building.
Applicability	Generally applicable to all types of buildings.
Baseline Standard	Nil.
Requirements	<p><u>3-1(a)</u></p> <ul style="list-style-type: none"> 1 point can be scored if the building management has an Environmental Policy that reflects sustainability goals set for the building and its systems. <p><u>3-1(b)</u></p> <ul style="list-style-type: none"> 1 point can be scored if the building management has a green guide which is disseminated to the building occupants and visitors to inculcate 'green' mindset. Best practices to reduce energy use, water use and maintain a good indoor environment should be documented in this green guide. Building management is also required to demonstrate evidences of occupant involvement in environmental sustainability. <p><u>3-1(c)</u></p> <ul style="list-style-type: none"> Up to 1 point can be scored if the in-house building management team comprises:- <ul style="list-style-type: none"> one Certified Green Mark Facilities Manager (GMFM) (0.5 point) or one Certified Green Mark Professional (GMP) (1 point) or one Singapore Certified Energy Manager (SCEM) (1 point). <p><u>3-1(d)</u></p> <ul style="list-style-type: none"> Up to 1 point can be scored if the environmental management system of the building is ISO 14000 or ISO 50001 certified.
Documentary Evidences	<p><u>3-1(a)</u></p> <ul style="list-style-type: none"> A copy of the Environmental Policy with endorsement or mandate by top management. <p><u>3-1(b)</u></p> <ul style="list-style-type: none"> A copy of the building green guide containing best practices for energy and water conservation and good indoor environment; and also the details of the environmental friendly facilities and features within the building and their uses in achieving the intended environment performance during building operation. Supporting documents on efforts/various avenues to disseminate the green guide to occupants and to inculcate 'green' mindset in occupants. <p><u>3-1(c)</u></p> <ul style="list-style-type: none"> Certified true copies of the certificate of GMFM or GMP or SCEM of in-house building management team and confirmation of their involvement and contribution in the Green Mark assessment.

	<p><u>3-1 (d)</u></p> <ul style="list-style-type: none"> • A certified true copy of the ISO 14000 or ISO 50001 certificates, which are within the validity period at the time of assessment. The scope of activities mentioned in the certificate shall be relevant to the building and/or building management/operations.
<p>References</p>	<ul style="list-style-type: none"> • The Environment Policy is a written commitment of the management's stance towards the building environment in which it operates. The policy shall outline management's intent to reduce its carbon footprint, improve recycling, minimizing waste, improve efficiencies of its building systems, etc. • It must be signed by top management to demonstrate that it is a company policy and reviewed at regular intervals. • The policy must be communicated to employees and others working on behalf of the management. • The policy shall also include a framework for continual improvement to environmental performance and pollution prevention and regulatory compliances.

ENRB 3-2 POST OCCUPANCY EVALUATION

Objectives	A post-occupancy evaluation is a survey which includes questions for building occupants about the building operations. These include thermal comfort, lighting quality, cleanliness, work environment, furniture and more. The objective is to gauge occupants' satisfaction on indoor environmental quality and identify corrective actions that will enhance comfort.
Applicability	Applicable to all buildings.
Baseline Standard	Satisfactory level of more than 80% to be achieved.
Requirements	<p><u>3-2(a)</u></p> <ul style="list-style-type: none"> • 2 points can be scored if building management conduct post occupancy survey to evaluate occupants' satisfaction on indoor environmental performance. • Required number of people surveyed shall be 10% of total occupancy and up to 100 maximum. A minimum 5 people shall be surveyed if total occupancy is less than 50. <p><u>3-2(b)</u></p> <ul style="list-style-type: none"> • 1 point can be scored for corrective actions taken following the post occupancy evaluation.
Documentary Evidences	<p><u>3-2(a)</u></p> <ul style="list-style-type: none"> • A written confirmation on the total no. of building occupancy. • Summary of the complete analysis of the survey forms. • Survey forms submitted by the respondents. <p><u>3-2(b)</u></p> <ul style="list-style-type: none"> • List of the corrective actions based on the respondents' comments. • Acknowledgement from the complainant on the action taken by the building management.
References	Nil.

ENRB 3-3 WASTE MANAGEMENT

Objectives	To reduce waste consumption by recycling, monitoring and educating the building occupants.
Applicability	Applicable to all buildings.
Baseline Standard	Nil.
Requirements	<p><u>3-3(a)</u></p> <ul style="list-style-type: none"> • 2 points can be scored for the provision of facilities or recycling bins for collection and storage of different recyclable waste such as paper, glass, plastic etc. <p><u>3-3(b)</u></p> <ul style="list-style-type: none"> • 2 points can be scored for the promotion of waste minimization and recycling among occupants, tenants and visitors. <p><u>3-3(c)</u></p> <ul style="list-style-type: none"> • 1 point can be scored for the provision of a proper storage area for the recyclable waste. <p><u>3-3(d)</u></p> <ul style="list-style-type: none"> • 2 points can be scored for quantifying the recyclables and monitoring the recycling program for continuous improvement. Recyclables include glass, paper, metal (including drinking cans), plastic and other wastes such as printer cartridges, food waste, etc.
Documentary Evidences	<p><u>3-3(a)</u></p> <ul style="list-style-type: none"> • Plan layout showing the location of the recycling bins for collection and storage of different recyclable wastes. <p><u>3-3(b)</u></p> <ul style="list-style-type: none"> • Supporting documents on efforts and avenues to educate occupants, tenants and visitors on waste reduction and recycling. <p><u>3-3(c)</u></p> <ul style="list-style-type: none"> • Plan layout showing the location of the storage area for the recyclable waste and the recycle bins for the different recyclables. <p><u>3-3(d)</u></p> <ul style="list-style-type: none"> • Details of monthly data collections and amount of recyclables generated in-house.
References	<ul style="list-style-type: none"> • Waste management at http://app2.nea.gov.sg/topics_waste.aspx • Waste minimization and recycling at http://app2.nea.gov.sg/topics_wasteminimisation.aspx

ENRB 3-4 SUSTAINABLE PRODUCTS

Objectives	Encourage the use of materials that are environmentally friendly and sustainable which are certified by approved local certification body.								
Applicability	Applicable to all buildings								
Baseline Standard	Nil.								
Requirements	<p>Up to 8 points are allocated for the use of environmentally friendly products that are certified by approved local certification body. Points awarded will be based on the weightage, extent of coverage and impact.</p> <p>The weightage given will be based on the extent of environmental friendliness and the rating as determined by the approved local certification body subject to BCA's evaluation.</p> <table border="1" data-bbox="440 846 1281 1066"> <thead> <tr> <th data-bbox="440 846 874 920">Extent of Environmental Friendliness of products</th> <th data-bbox="874 846 1281 920">Weightage for Point Allocation</th> </tr> </thead> <tbody> <tr> <td data-bbox="440 920 874 969">Good</td> <td data-bbox="874 920 1281 969">1</td> </tr> <tr> <td data-bbox="440 969 874 1019">Very Good</td> <td data-bbox="874 969 1281 1019">1.5</td> </tr> <tr> <td data-bbox="440 1019 874 1066">Excellent</td> <td data-bbox="874 1019 1281 1066">2</td> </tr> </tbody> </table> <p>The use of environmental friendly products used for the main building elements or functional spaces will be considered as <u>high impact</u> if the quantities used by percentage are more than 50% (i.e. extent of coverage) as compared to the total quantities used for the same intended purpose. Items that do not meet the minimum coverage or are used in other common areas, external works etc will be considered as <u>low impact</u>.</p> <p>Note: The point allocated for low volatile organic compound (VOC) paints and adhesives certified by approved local certification body can be found in ENRB 4-2 and hence shall not be included in the scoring for ENRB 3-4.</p>	Extent of Environmental Friendliness of products	Weightage for Point Allocation	Good	1	Very Good	1.5	Excellent	2
Extent of Environmental Friendliness of products	Weightage for Point Allocation								
Good	1								
Very Good	1.5								
Excellent	2								
Documentary Evidences	<ul style="list-style-type: none"> • Certification from approved local certification body (such as SGLS and SGBC) which should spell out the material certification standards, rating and details. • Technical product information. 								
References	<ul style="list-style-type: none"> • Singapore Green Building Product certification Certified products : http://www.sgbc.sg/index.php/certification/assess/C109/ Scoring method : http://www.sgbc.sg/index.php/certification/cert_fags/ • Singapore Environmental Council at http://www.greenlabel.sg/sxls 								

Worked Example 3-4(i)

1. Determine if the environmental friendly products selected are certified with approved certification body and the product rating.
2. Check if the products used are meant for main building elements or functional spaces and can be considered as high impact. Examples are internal drywall partitions in every functional space unit, carpets for office spaces, etc. Products that are meant for common areas and external works such as toilets, lobbies and landscaping areas are considered as low impact.
3. If the selected products are potential high impact items, then determine the quantities used for these products as compared to the total quantities required for the same intended purpose. If the quantities of the products are more than 50% of the total requirement, it is considered as high impact. If it is less than 50% of the total requirement then it should be considered as low impact.

Example of products that are rated as 'Good' by the approved local certification body.

Products and Extent of coverage		With approved certification	Points allocated based on impact	Weightage based on rating	Points scored
(a)	Carpets for all office spaces	Yes	1	1	1
(b)	Panel boards as internal partition for more than 50% of office spaces	Yes	1	1	1

Points scored for 3-4 (i) = 1+1 = 2 points

Worked Example 3-4(ii)

Note: Certain products have more environmentally friendly features than others. Other than recycled materials, they may have added features like low VOC assembly or manufactured with resource efficient processes, durability etc which will render the products more environmental superior than others. If the certified products selected are more environmental superior products and are rated by the approved local certification body as of better rating, higher weightage will be given in term of point scoring.

Example of a proposed development with the following provisions:

- (a) Use of carpets for all office spaces. Product is not certified.
- (b) Use of panel boards as internal partitions for more than 50% of the office spaces and the product is rated to be 'Very Good' by the approved certification body.
- (c) Precast concrete road kerbs. Product is rated as 'Good' by approved local certification body.
- (d) Use of roof waterproofing coating. Product is rated as 'Very Good' by approved local certification body.
- (e) Use of wooden doors for all areas. Product is rated as 'Excellent' by approved local certification body.

**Worked
Example
3-4(ii)**

Products and Extent of coverage		With approved certification	Points allocated based on impact (A)	Weightage based on rating (B)	Points scored (AxB)
(a)	Carpets for all office spaces	No	NA	NA	0
(b)	Panel boards as internal partition for more than 50% of office spaces	Yes	1	1.5	1.5
(c)	Precast road kerbs	Yes	0.5	1	0.5
(d)	Roof waterproofing	Yes	0.5	1.5	0.75
(e)	Wooden doors for all areas	Yes	1	2	2

Therefore, points scored for 3-2 (ii) = $1.5 + 0.5 + 0.75 + 2 = 4.75$ points

ENRB 3-5 GREENERY PROVISION

Objectives	Encourage greater use of greenery to reduce heat island effect.										
Applicability	Applicable to buildings with landscaping areas.										
Baseline Standard	Nil.										
Requirements	<p><u>3-5(a)</u></p> <ul style="list-style-type: none"> Up to 5 points can be scored for the provision of greenery within the developments including roof top/ sky garden and green roof and vertical greening. Greenery Provision (GnP) is calculated by considering the 3D volume covered by plants using the following Green Area Index (GAI) : Grass GAI = 1 ; Shrubs GAI = 3; Palms Trees GAI = 4; Trees GAI = 6 <p>Greenery Provision (GnP) = Total Green Area / Total Site Area</p> <table border="1" data-bbox="443 887 995 1077"> <thead> <tr> <th>GnP</th> <th>Points Allocation</th> </tr> </thead> <tbody> <tr> <td>0.5 to < 1.0</td> <td>1</td> </tr> <tr> <td>1.0 to < 2.0</td> <td>2</td> </tr> <tr> <td>2.0 to < 3.0</td> <td>3.5</td> </tr> <tr> <td>≥ 3.0</td> <td>5</td> </tr> </tbody> </table> <p><u>3-5(b)</u></p> <ul style="list-style-type: none"> 1 point for the use of compost recycled from horticulture waste and/or organic compost. <p><u>3-5(c)</u></p> <ul style="list-style-type: none"> Provision of roof top greenery: 1 point for ≥20% to 50% of useable roof areas and 2 points for ≥ 50% of useable roof areas. <p><u>3-5(d)</u></p> <ul style="list-style-type: none"> Provision of vertical greenery: 1 point for ≥10m² to <50m² greenery areas and 2 points for ≥ 50m² greenery areas. 	GnP	Points Allocation	0.5 to < 1.0	1	1.0 to < 2.0	2	2.0 to < 3.0	3.5	≥ 3.0	5
GnP	Points Allocation										
0.5 to < 1.0	1										
1.0 to < 2.0	2										
2.0 to < 3.0	3.5										
≥ 3.0	5										
Documentary Evidences	<p><u>For 3-5(a)</u></p> <ul style="list-style-type: none"> Plan layouts showing the site area as well as the greenery that is provided within the development; Calculation showing the extent of the greenery provision in the prescribed tabulated format as in worked example 3-5(a). <p><u>For 3-5(b)</u></p> <ul style="list-style-type: none"> Documentary evidences stating the compost used is made from recycled horticulture waste and/or organic compost with certification from approved local certification body. Horticulture waste is manufactured from grass, leaves and tree clippings. 										

	<p><u>For 3-5(c)</u></p> <ul style="list-style-type: none"> Plan layouts showing the greenery area on the roof top and the calculation of the percentage area compared to useable total roof area. <p><u>For 3-5(d)</u></p> <ul style="list-style-type: none"> Plan layouts showing the vertical greenery area and the calculation of this area. 																																				
References	Nil.																																				
Examples	<ol style="list-style-type: none"> Determine the number of trees, palms and the areas for shrub and turfs and other greenery area The canopy, radius and Green Area Index are pre-determined design parameters applicable for all developments. Compute the green areas as shown in the Table 3-5(a) below. <p>Table 3-5(a) – Calculation of the Greenery Provision</p> <table border="1"> <thead> <tr> <th>Description</th> <th>Qty (A)</th> <th>Canopy area (B)</th> <th>Radius (C)</th> <th>Green Area Index GAI</th> <th>Green Area (A)x(B)x(C²)xGAI</th> </tr> </thead> <tbody> <tr> <td>Trees (Nos)</td> <td>20</td> <td>3.14</td> <td>3.5</td> <td>6</td> <td>4615.8</td> </tr> <tr> <td>Palms (Nos)</td> <td>20</td> <td>3.14</td> <td>1</td> <td>4</td> <td>251.2</td> </tr> <tr> <td>Shrubs (m²)</td> <td>20</td> <td>NA</td> <td>NA</td> <td>3</td> <td>60</td> </tr> <tr> <td>Landscape area + Roof garden + vertical greening (m²)</td> <td>100</td> <td>NA</td> <td>NA</td> <td>1</td> <td>100</td> </tr> <tr> <td colspan="5" style="text-align: right;">Total Green Area :</td> <td>5027</td> </tr> </tbody> </table> <p>Assume site area is 4000m²</p> <p>Greenery Provision (GnP) = Total Green Area / Total Site Area = 5027 / 4000 = 1.26 (1.0 to <2.0)</p> <p>Therefore, points scored for 3-5(a) = 2 points</p>	Description	Qty (A)	Canopy area (B)	Radius (C)	Green Area Index GAI	Green Area (A)x(B)x(C ²)xGAI	Trees (Nos)	20	3.14	3.5	6	4615.8	Palms (Nos)	20	3.14	1	4	251.2	Shrubs (m ²)	20	NA	NA	3	60	Landscape area + Roof garden + vertical greening (m ²)	100	NA	NA	1	100	Total Green Area :					5027
Description	Qty (A)	Canopy area (B)	Radius (C)	Green Area Index GAI	Green Area (A)x(B)x(C ²)xGAI																																
Trees (Nos)	20	3.14	3.5	6	4615.8																																
Palms (Nos)	20	3.14	1	4	251.2																																
Shrubs (m ²)	20	NA	NA	3	60																																
Landscape area + Roof garden + vertical greening (m ²)	100	NA	NA	1	100																																
Total Green Area :					5027																																

ENRB 3-6 ENVIRONMENTAL PROTECTION

Objectives	To encourage the adoption of sustainable and environmental friendly procurement and purchasing policy in the operation and maintenance of the building and the use of environmentally friendly refrigerant in the air-conditioning system.
Applicability	Generally applicable to all buildings.
Baseline Standard	Nil.
Requirements	<p><u>3-6(a)</u></p> <ul style="list-style-type: none"> • 1 point can be scored for the adoption of sustainable and environmental friendly procurement and purchasing policy in the operation and maintenance of the building. <p><u>3-6(b)(i)</u></p> <ul style="list-style-type: none"> • 1 point can be scored for using refrigerants with ozone depletion potential (ODP) of zero and with global warming potential (GWP) of less than 100. <p><u>3-6(b)(ii)</u></p> <ul style="list-style-type: none"> • 1 point can be scored for installing a refrigerant leak detection system at critical areas of the plant rooms with chillers and other equipment with refrigerants.
Documentary Evidences	<p><u>For 3-6(a)</u></p> <ul style="list-style-type: none"> • Documentary evidences stating management's green procurement policy and extracts of tender specification or quotation for environmental friendly products. <p><u>For 3-6(b)</u></p> <ul style="list-style-type: none"> • Extracts of technical specification or photographs of chiller's or condensing unit's name plate that shows refrigerant used for the chillers. • Technical specification and/or drawings/photographs showing the refrigerant leak detection system.
References	<p><u>Green Procurement Policy</u></p> <p>The goal of this policy is to reduce the adverse environmental impact of building owners' purchasing decisions by buying goods and services from contractors and vendors who are committed to environmental sustainability.</p> <p>The following are some strategies for this Policy:-</p> <ol style="list-style-type: none"> a) Purchase only most up-to-date energy efficient equipment, where applicable. This includes, but not limited to air-conditioning system, lightings and office appliances. b) Purchase only readily biodegradable and phosphate free cleaning detergents and products that meet approved certification standards and have eco-labels such as Singapore Green Label Scheme (SGLS). c) Purchase only bio-based plastic products that are biodegradable and compostable, such as bags, food and beverage containers, and cutlery.

	<p>d) For building maintenance, purchase products/materials such as paint, carpeting, adhesives and furniture, with the lowest amount of volatile organic compounds (VOCs), highest recycled content, and low or no formaldehyde.</p> <p>e) For landscape maintenance, to employ landscape contractors who are familiar with sustainable landscape management techniques such as, drip irrigation, composting and use of mulch and compost produced from regionally generated plant debris and/or food waste.</p>
--	---

Objectives	Promote the use of public transport and environmental friendly transport options to reduce pollution from individual car use.
Applicability	Generally applicable to all buildings.
Baseline Standard	Nil.
Requirements	<p><u>3-7(a)</u></p> <ul style="list-style-type: none"> • 1 point can be scored if building has good access (< 500m walking distance) to public transport networks such as MRT/LRT stations and bus stops. <p><u>3-7(b)</u></p> <ul style="list-style-type: none"> • 1 point can be scored for provision of covered walkway to facilitate connectivity and use of public transport. <p><u>3-7(c)</u></p> <ul style="list-style-type: none"> • 1 point can be scored for provision of adequate priority parking lots for hybrid/electric vehicle within the development. <p><u>3-7(d)</u></p> <ul style="list-style-type: none"> • Up to 1 point can be scored for the provision of covered/sheltered bicycles parking lots with adequate shower facilities. <i>(Minimum provision of 10 bicycle parking lots; cap at 30 bicycle parking lots where applicable) :</i> <ul style="list-style-type: none"> - 1 point if the number of bicycles parking lots is $\geq 1\% \times (\text{GFA}/10)$ - 0.5 point if the number of bicycles parking lots is $\geq 0.5\% \times (\text{GFA}/10)$
Documentary Evidences	<p><u>For 3-7(a)</u></p> <ul style="list-style-type: none"> • Site layout plan in the context of the surrounding area showing the location of the building and the location of the MRT/LRT stations and bus stops. <p><u>For 3-7(b)</u></p> <ul style="list-style-type: none"> • Site layout plan showing the connection of covered walkway from the development to the MRT/LRT stations or bus stops; and • Documentary evidences or letter of commitment stating the requirement to provide covered walkway. <p><u>For 3-7(c)</u></p> <ul style="list-style-type: none"> • Documentary evidences or letter of commitment stating the requirement to provide priority parking lots for hybrid/electric vehicle. <p><u>For 3-7(d)</u></p> <ul style="list-style-type: none"> • Documentary evidences or letter of commitment stating the requirement to provide covered/sheltered bicycles parking lots, shower and changing facilities for the development and the quantity and location of bicycle lots provided. The shower and changing facilities shall be accessible to the cyclists.
References	Nil.

**Worked
Example**

3-7(d)

Example 1

An existing building has a Gross Floor Areas (GFA) of 12,000 square metres.

Minimum number of bicycle parking lots = $1\% \times (12000/10) = 12$ lots
(with adequate shower facilities)

Minimum number of bicycle parking lots = $0.5\% \times (12000/10) = 6$ lots
(with adequate shower facilities)

1 point will be scored if the number of bicycles parking lots provided ≥ 12 lots.

0.5 point will be scored if the number of bicycles parking lots provided ≥ 10 lots
with adequate shower facilities.

Since the minimum provision of 10 bicycles parking lots is required, no points given
if the number of bicycles parking lots provided is < 10 lots.

Example 2

An existing building has a Gross Floor Areas (GFA) of 70,000 square metres.

Minimum number of bicycle parking lots = $1\% \times (70000/10) = 70$ lots
(with adequate shower facilities) (1 point)

Minimum number of bicycle parking lots = $0.5\% \times (70000/10) = 35$ lots
(with adequate shower facilities) (0.5 point)

1 point will be scored if the number of bicycles parking lots provided is 30 lots with
adequate shower facilities.

Note : Cap at 30 bicycles parking lots

(II) Other Green Requirements

Part 4 – Indoor Environmental Quality

ENRB 4-1	Indoor Air Quality (IAQ)
ENRB 4-2	Indoor Air Pollutants
ENRB 4-3	Lighting Quality
ENRB 4-4	Thermal Comfort
ENRB 4-5	Internal Noise Level

ENRB 4-1 INDOOR AIR QUALITY PERFORMANCE

Objectives	Ensure building ventilation systems are designed and installed to provide acceptable IAQ under normal operating conditions.
Applicability	Applicable to all air-conditioned buildings.
Baseline Standard	-
Requirements	<p><u>4-1(a) Pre-requisite Requirement</u> 4 points can be scored for performing full IAQ audit by an accredited laboratory under Singapore Accreditation Council. Results of audit shall comply with NEA's Guidelines for Good Indoor Air Quality in Office Premises or SS554:2009 Code of Practice for Indoor Air Quality for Air-conditioned Buildings.</p> <p><u>4-1(b)</u> 1 point can be scored for implementing effective IAQ management plan to ensure that building ventilation systems are frequently maintained to ensure clean delivery of air.</p> <p><u>4-1(c)</u> 1 point can be scored for the provision of high efficiency air filter (at least MERV 13) in Air Handling Units.</p> <p><u>4-1(d)</u> 1 point can be scored for providing Room Temperature display (at least 1 unit per floor).</p> <p><u>4-1(e)</u> 1 point can be scored for providing Carbon Dioxide sensor display (at least 1 unit per floor).</p>
Documentary Evidences	<p><u>For 4-1(a)</u></p> <ul style="list-style-type: none"> • IAQ audit results/report by an accredited laboratory. <p><u>For 4-1(b)</u></p> <ul style="list-style-type: none"> • Document or report on the implementation of the IAQ management plan. <p><u>For 4-1(c)</u></p> <ul style="list-style-type: none"> • Technical product information which should include the minimum efficiency reporting value (MERV) parameters of the filters; <p><u>For 4-1(d)</u></p> <ul style="list-style-type: none"> • Layout plan showing the location of Room Temperature display. <p><u>For 4-1(e)</u></p> <ul style="list-style-type: none"> • Layout plan showing the location of Carbon Dioxide sensor display.

References	<ul style="list-style-type: none">• NEA's Guidelines for Good Indoor Air Quality in Office Premises• SS 554:2009 - Code of Practice for Indoor Air Quality for Air-conditioned Buildings• IAQ management programme, refer to guidelines given in Annex G of SS554:2009 Code of Practice for Indoor Air Quality for Air-conditioned Buildings.• Air filter classification can be found in Annex E of SS554:2009 Code of Practice for Indoor Air Quality for Air-conditioned Buildings.
-------------------	--

ENRB 4-2 INDOOR AIR POLLUTANTS

Objectives	Minimise airborne contaminants, mainly from inside sources to promote a healthy indoor environment.
Applicability	Generally applicable to all building developments.
Baseline Standard	Nil
Requirements	<p><u>4-2(a)</u> 1 point can be scored for the use of low volatile organic compounds (VOC) paints certified under approved local certification body.</p> <p><u>4-2(b)</u> 1 point can be scored for the use of adhesives certified by approved local certification body.</p>
Documentary Evidences	<p><u>For 4-2(a)</u></p> <ul style="list-style-type: none"> • Layout plans and/or documentary evidences showing areas using the low VOC paints. • Certification by approved local certification body. • Technical specification of the low VOC paints. <p><u>For 4-2(b)</u></p> <ul style="list-style-type: none"> • Documentary evidences on the use of the adhesives. • Certification by approved local certification body. • Technical specification of the adhesives.
References	Nil.

ENRB 4-3 LIGHTING QUALITY

Objectives	To encourage good workplace lighting quality to promote productivity and occupant comfort.
Applicability	Generally applicable to all internal areas.
Baseline Standard	Schedule of lighting requirements stated in SS531:Part 1:2006 or CP 38:1999.
Requirements	<p><u>4-3(a)</u></p> <ul style="list-style-type: none"> 1 point can be scored if the lighting levels comply with SS531 or CP38:1999 for various uses. <p><u>4-3(b)</u></p> <ul style="list-style-type: none"> 1 point can be scored if at least 90% of occupants are able to control lightings by light switches. 2 point can be scored if at least 90% of occupants are able to control lightings by task lightings. <p><u>4-3(c)</u></p> <ul style="list-style-type: none"> Up to 2 points can be scored for the use of high frequency ballasts in the fluorescent lightings if it is adopted in all applicable areas that are served by fluorescent lightings. <ul style="list-style-type: none"> 20% to < 40% - 0.5 point 40% to < 60% - 1 point 60% to < 80% - 1.5 points 80% and above - 2 points
Documentary Evidences	<p><u>For 4-3(a)</u></p> <ul style="list-style-type: none"> Tabulation of lux level measurements and plan layout showing the location of the measurements taken. <p><u>For 4-3(b)</u></p> <ul style="list-style-type: none"> Tabulation of areas where task lights or light switches are used. <p><u>For 4-3(c)</u></p> <ul style="list-style-type: none"> A summary sheet listing all fluorescent lightings used for the developments and those with high frequency ballasts. Technical specification for the high frequency ballasts used in all fluorescent luminaries.
References	<p>CP 38:1999 : Code of Practice for Artificial Lighting in Buildings</p> <p>SS 531:Part 1:2006 : Code of Practice for Lighting of Work Places Part 1 – Indoor Lighting</p>

ENRB 4-4 THERMAL COMFORT

Objectives	To encourage buildings to maintain good indoor conditions for thermal comfort.
Applicability	Generally applicable to all indoor air-conditioned environment.
Baseline Standard	Indoor conditions for comfort air-conditioning as stated in CP 13:1999.
Requirements	<p><u>4-4(a)</u></p> <ul style="list-style-type: none">• 1 point can be scored if the indoor dry-bulb temperature is within 22.5 °C to 25.5 °C and relative humidity <70%. <p><u>4-4(b)</u></p> <ul style="list-style-type: none">• 1 point can be scored if occupants are able to control the indoor temperature.
Documentary Evidences	<ul style="list-style-type: none">• Tabulation of temperature and relative humidity measurements and plan drawings indicating locations of sampled points taken.• Tabulation of areas where temperature can be controlled by thermostats.
References	CP 13:1999 – Code of Practice for Air-Conditioning and Mechanical Ventilation in Buildings.

ENRB 4-5 INTERNAL NOISE LEVEL

Objectives	To control and keep the background noise in occupied spaces at levels appropriate to the intended use of the spaces.
Applicability	Generally applicable to all building developments.
Baseline Standard	Recommended ambient sound level in CP 13:1999 or SS 553:2009.
Requirements	1 point can be scored if the occupied spaces in buildings are maintained at the recommended ambient sound levels stated in CP 13:1999 or SS 553:2009.
Documentary Evidences	<ul style="list-style-type: none">• Tabulation of sound levels measurements and comparison with the recommended sound levels in CP 13:1999 or SS 553:2009.• Plan drawings indicating locations of sampled points taken.
References	CP 13:1999 – Code of Practice for Air-Conditioning and Mechanical Ventilation in Buildings. SS 553:2009 - Code of Practice for Air-Conditioning and Mechanical Ventilation in Buildings.

(II) Other Green Requirements

Part 5 – Other Green Features

ENRB 5-1 Green Features and Innovations

ENRB 5-1 OTHER GREEN FEATURES

Objectives	Encourage the use of green features which are innovative and have positive environmental impact on water efficiency, environmental protection and indoor environmental quality of the buildings.
Applicability	Generally applicable to all building developments.
Baseline Standard	Nil.
Requirements	<p>Up to 10 points can be scored for the use of the non-energy related green features depending on their potential environmental benefits or reduced environmental impacts. Examples of the green features are:-</p> <p><u>Water Efficiency</u></p> <p>(i) Use of self cleaning façade system</p> <ul style="list-style-type: none"> • 2 points for more than 75% of the applicable facade areas • 1 point for more than 50% of the applicable facade areas • 0.5 point for at least 25% of the applicable facade areas <p>(ii) Use of grey water recycling system</p> <ul style="list-style-type: none"> • 2 points for all blocks of the development • 1 point for at least one block of the development <p>(iii) Recycling of AHU condensate</p> <ul style="list-style-type: none"> • 1 point for more than 75% of the AHU condensate • 0.5 point for at least 50% of the AHU condensate <p><u>Environmental Protection</u></p> <p>(i) 0.5 point for the use of non-chemical termite treatment system such as termite baiting system, anti-termite mesh.</p> <p>(ii) 0.5 point for the provision of at least 5 nos. of compost bins to recycle organic waste.</p> <p>(iii) 0.5 point for the use of non-chemical water treatment system for swimming pools.</p> <p>(iv) 1 point for the provision of double refuse chutes for separating recyclable from non-recyclable waste.</p> <p>(v) Treatment of storm water runoff before discharge to public drains.</p> <ul style="list-style-type: none"> • 2 points for treatment of run-off for more than 10% of total site area • 1 point for treatment of run-off for up to 10% of total site area <p>Note: The treatment of storm water runoff shall be through provision of infiltration features or design features as recommended in PUB's ABC Water design Guidelines.</p>

	<p>(vi) 0.5 point for use of new generation of refrigerants with ODP =0 and GWP <150.</p> <p><u>Indoor Air Quality</u></p> <p>(i) 1 point for the use of pneumatic waste collection system.</p> <p>(ii) Use of Ultraviolet light-C band (UV) emitters in air handling units to improve indoor air quality.</p> <ul style="list-style-type: none"> • 1 point for more than 75% of the AHU have this emitter • 0.5 point for at least 50% of the AHU have this emitter <p>(iii) Use of at least MERV 14 or equivalent – 0.5 point</p> <p><u>Others</u></p> <p>(i) 0.5 point for the use of siphonic rainwater discharge system at roof.</p> <p>(ii) 0.5 point for the provision of carpark guidance system.</p> <p>(iii) 1 point for having Green Lease arrangement for building tenants.</p> <p>(iv) 0.5 points for the use of Titanium Dioxide coating to remove odour in toilets.</p> <p>(v) 0.5 points for the use of automatic condenser tube cleaning system for the chillers.</p> <p>(vi) Encourage tenants to take up Green Mark Occupant Centric Schemes (cap at 2 points).</p> <ul style="list-style-type: none"> • 0.5 point for having at least 3 tenant certified under Green Mark Occupant-Centric Schemes • 1 point for achieving Green Mark Pearl Award • 2 points for achieving Green Mark Pearl Prestige Award <p>(vii) Provision of Green Corner, which is an area dedicated to education and promotion on green and environmental sustainability. It must be located at prominent location/s, where occupants have easy access to it.</p> <ul style="list-style-type: none"> • 0.5 point for having posters and displays on green and sustainability. • 1 point for having screen showing the building’s real time energy performance. <p>(viii) Install power meters for monitoring of air side system (cap at 2 points).</p> <ul style="list-style-type: none"> • 0.5 point for installing power meters to all air side system and link up to BMS for ease of monitoring and calculating total system kw/ton. • 1 point for achieving 0.28 kw/ton (Total air side system kWh / total cooling load Rtonh) • 2 points for achieving 0.25 kw/ton (Total air side system kWh / total cooling load Rtonh) <p>(ix) 1 point for having an energy performance contract with a SGBC accredited Energy Performance Contracting Firm that guarantees the operational system efficiency of a chiller plant. The contract should at least be valid for the next 3 years.</p>
<p>Documentary Evidences</p>	<ul style="list-style-type: none"> • Write-up describing the provision of the green features and the extent of implementation.

	<ul style="list-style-type: none">• Technical product information (including drawings and supporting documents) of the green features;• Details showing the positive environmental impact and benefits that the features can bring to the building.
References	-